

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600352
DATE : 23.02.2026
REQ No : 1032505161
REQ TITLE : Refurbishment of CLO2 skid pi
DELIVERY LOCATION
CLOSING DATE : 27.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	<p>CONTRACTOR SHALL CONDUCT A JOINT SITE ASSESSMENT WITH THE DEWA ENGINEER PRIOR TO COMMENCEMENT OF ANY WORK. # ALL ACTIVITIES SHALL COMPLY WITH DEWA SAFETY POLICY, INCLUDING CHEMICAL HANDLING PROCEDURES AND CLO# SAFETY REQUIREMENTS. # ALL PIPING, FITTINGS, AND ACCESSORIES SHALL BE PVC OR CPVC AND FULLY COMPATIBLE WITH CLO#, HCL, AND NACLO. # PROPER FLUSHING AND NEUTRALIZATION PROCEDURES MUST BE COMPLETED BEFORE DISMANTLING ANY EXISTING CHEMICAL LINES. # ALL NEWLY INSTALLED COMPONENTS SHALL BE CLEARLY LABELED AND TAGGED AS PER DEWA STANDARDS (WHERE APPLICABLE). 2. DISMANTLING WORKS # REMOVE ALL EXISTING PVC/CPVC CHEMICAL DOSING PIPING, VALVES, AND ASSOCIATED FITTINGS. # DISPOSE OF ALL DISMANTLED MATERIALS 3. PIPING AND FITTINGS INSTALLATIONS SCOPE # SUPPLY, FABRICATE, AND</p>	4	NO				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600352
DATE : 23.02.2026
REQ No : 1032505161
REQ TITLE : Refurbishment of CLO2 skid pi
DELIVERY LOCATION
CLOSING DATE : 27.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			INSTALL NEW CLO# DOSI NG PIPING INCLUDED WORKS# #INSTALL NEW PIPING FROM HCL AND BIOCAF (NACLO#) STORAGE TANKS TO THEIR RESPECTIVE DOSING SKIDS.# #PROVIDE A ND INSTALL ALL REQUIRED FITTINGS INCLUDING UNIONS, ELBOWS, TEES, REDUCERS, ISOLATION VALVES, AND OTHER ACCESSORIES.# #REPLACE ALL EXI STING VALVES WITH NEW CHEMICAL#RESISTANT TYPES, INCLUDING:# #BALL VALVES# #CHECK VALVES# #PRESSURE RELIEF VALVES# #PRESSURE GAUGES# # FLOW INDICATORS# #PERFORM SYSTEM CALIBRATION, PRESSURE TESTING, AND LEAK TESTING UPON COMPLETION OF INSTALLATION.# #SUBMIT COMPLETE A S#BUILT DRAWINGS, MATERIAL SUBMITTALS, AND A DETAILED LIST OF ALL INSTALLED COMPONENTS.						
2		ITEM-00001	1. GENERAL REQUIREMENTS:# #CONTRACTOR TO PERFORM A JOINT SITE ASSESSMENT WITH THE DEWA ENGINEER BEFORE STARTING WORK.# #ALL WORKS SHA	2	NO				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600352
DATE : 23.02.2026
REQ No : 1032505161
REQ TITLE : Refurbishment of CLO2 skid pi
DELIVERY LOCATION
CLOSING DATE : 27.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>LL COMPLY WITH DEWA SAFETY POLICY, INCLUDING CHEMICALHANDLING AND CLO# SAFETY PROCEDURES.# #ALL PIPING AND FITTINGS MUST PRESSURE-RATED AND FULLY COMPATIBLEWITH CLO#, HCL, AND NACLO#.# #CONTRACTOR TO VERIFY CHEMICAL COMPATIBILITY FOR MATERIALS.# #PROPER FLUSHING AND NEUTRALIZATION PROCEDURES MUST BE FOLLOWEDBEFORE DISMANTLING EXISTING CHEMICAL LINES.# #ALL INSTALLED PARTS TO BE LABELED AND TAGGED CLEARLY (IFAPPLICABLE).# #CONTRACTOR TO PROVIDE METHOD STATEMENTS, DAILY TOOLBOX TALK, RISKASSESSMENTS FOR DEWA APPROVAL BEFORE STARTING WORK.2. DISMANTLING WORKS# #DISMANTLE ALL EXISTING CHEMICAL DOSING PIPING, VALVES, FITTINGS, ANDACCESSORIES.# #SAFE ISOLATION OF CHEMICAL LINES WILL BE PROVIDED BY DEWA BEFOREDISMANTLING.# #PROPER DISPOSAL OF REMOVED MATERIALS.# #ENSURE NO DAMAGE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600352
DATE : 23.02.2026
REQ No : 1032505161
REQ TITLE : Refurbishment of CLO2 skid pi
DELIVERY LOCATION
CLOSING DATE : 27.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>TO EXIST ING EQUIPMENT, STRUCTURES, OR CABLE TRAYS DURING DISMANTLING.3. PIPING AND FITTINGS INSTALLATION3.1 SUPPLY & INSTALLATION# #SUPPLY AN D INSTALL NEW CLO##COMPATIBLE PIPING FROM THE CLO# SKIDS TO THE FOUR DOSING POINTS:# #CHLORINE CONTACT TANK# #PERMEATE HEADER# #SEAWA TER INTAKE# #PRODUCT WATER PUMP# #PROVIDE ALL REQUIRED FITTINGS: UNIONS, ELBOWS, TEES, REDUCERS, ISOLATION VALVES, SUPPORTS, CLAMPS, AND ANCHORS.# #REPLACE ALL EXISTING VALVES WITH NEW CHEMICAL#RESISTANT VALVES, INCLUDING:# #BALL VALVES# #CHECK VALVES# #PRESSURE REL IEF VALVES# #PRESSURE GAUGES# #FLOW INDICATORS# #ENSURE NO SHARP BENDS OR STRESS POINTS THAT MAY CAUSE FUTURE LEAKS.3.2 TESTING & CO MMISSIONING# #PERFORM HYDROSTATIC OR PNEUMATIC LEAK TESTING (AS APPLICABLE) IN</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600352
DATE : 23.02.2026
REQ No : 1032505161
REQ TITLE : Refurbishment of CLO2 skid pi
DELIVERY LOCATION
CLOSING DATE : 27.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			THE PRESENCE OF THE DEWA ENGINEER.# #PROVIDE COMMISSIONING SUPPORT UNTIL DEWA ACCEPTANCE.4. DOCUMENTATION# #SUBMIT AS#BUILT DRAWINGS SHOWING FINAL ROUTING, PIPE SIZES, VALVE LOCATIONS, AND SUPPORTS.# #PROVIDE A COMPLETE LIST OF INSTALLED COMPONENTS WITH MODEL NUMBERS AND MATERIAL SPECIFICATIONS.# #PROVIDE MANUFACTURER DATA SHEETS FOR ALL VALVES, FITTINGS, AND PIPING.# #SUBMIT TEST REPORTS						
3		ITEM-00001	STRUCTURAL & SUPPORTS REFURBISHMENT # ENHANCED SCOPE OF WORK: REMOVAL & PREPARATION WORKS# #SAFELY DISCONNECT AND REMOVE ALL CORRODED FITTINGS, PIPE SUPPORTS, CLAMPS, BRACKETS, AND STRUCTURAL ELEMENTS.# #ENSURE NO DAMAGE TO EXISTING PIPING, CABLES, INSTRUMENTS, OR EQUIPMENT DURING REMOVAL.# #COLLECT AND DISPOSE OF ALL REMOVED MATERIALS# #PERFORM SURFACE PREPARATION ON SKID	1	LOT				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600352
DATE : 23.02.2026
REQ No : 1032505161
REQ TITLE : Refurbishment of CLO2 skid pi
DELIVERY LOCATION
CLOSING DATE : 27.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>FRAMES, SUPPORT STRUCTURES, AND METALLIC COMPONENTS, INCLUDING: #MECHANICAL CLEANING# #SURFACE DEGREASING AND CLEANING PRIOR TO COATING# STRUCTURAL REFURBISHMENT & SUPPORT INSTALLATION# #REPAIR OR REPLACE ANY DAMAGED OR CORRODED STRUCTURAL MEMBERS OF THE SKID FRAME.# #SUPPLY AND INSTALL NEW PIPE SUPPORT, CLAMPS, U-BOLTS, BRACKETS, AND HANGERS AS REQUIRED.# #ADD ADDITIONAL SUPPORTS WHERE EXISTING SPACING IS INSUFFICIENT OR WHERE NEW LOADS REQUIRE REINFORCEMENT.# #ENSURE ALL SUPPORTS ARE PROPERLY ALIGNED, ANCHORED, AND VIBRATION ISOLATED (IF APPLICABLE).# #ALL NEW SUPPORTS MUST BE CORROSION RESISTANT (GALVANIZED STEEL, STAINLESS STEEL, OR EPOXY COATED STEEL DEPENDING ON DEWA REQUIREMENT). COATING & PAINTING INTERIOR WALL PAINTING OF SKID AREA# #APPLY PRIMER AND</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600352
DATE : 23.02.2026
REQ No : 1032505161
REQ TITLE : Refurbishment of CLO2 skid pi
DELIVERY LOCATION
CLOSING DATE : 27.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			COATS OF CHEMICAL#RESISTANT WALL PAINT SUITABLE FORIN DUSTRIAL ENVIRONMENTS.						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

Refurbishment of CLO2 skid pipings in Palm Jumeirah RO Plant

For more info: Mohammad.ali1@dewa.gov.ae (04-3226226);

sampreeth.palanna@dewa.gov.ae

STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600352
DATE : 23.02.2026
REQ No : 1032505161
REQ TITLE : Refurbishment of CLO2 skid pi
DELIVERY LOCATION
CLOSING DATE : 27.02.2026
CLOSING TIME : 10:00:00

5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

6) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer.

If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements
The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP