

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412600363  
**DATE** : 25.02.2026  
**REQ No** : 1032600242  
**REQ TITLE** : URGENT REQUIREMENT:  
**DELIVERY LOCATION**  
**CLOSING DATE** : 03.03.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	<p>REMOVAL OF INTERLOCK, EXCAVATION, EXPOSING GRE FIRE WATER PIPELINE, 150MM DIAMETER GRE PIPE LEAK RECTIFICATION, SERVICE PRESSURE TES</p> <p>T POST LEAKRECTIFICATION BY NORMALIZING THE SYSTEM, BACK FILLING, COMPACTION,INTERLOCK TILES REFIXING AND REINSTATEMENT OF AREA INSI</p> <p>DE NATURAL GASSTATION AT H-STATION, PHASE-1, AL-AWEER.SCOPE OF WORK:CONTRACTOR TO CONSIDER FOLLOWING WORK</p> <p>SCOPE,PRELIMINARY PREPARAT</p> <p>ORY WORKS:1.#EXCAVATE A TRIAL PIT OF 80 CM WIDTH TO LOCATE THE LEAK AREA ANDFULLY EXPOSE THE EXISTING GRE PIPELINE, FOLLOWING THE EN</p> <p>GINEER#SINSTRUCTIONS IN THE CENTRALLY MARKED RED ZONE.A.#FIX WORK</p> <p>SCOPE:1.#REMOVAL OF INTERLOCK TILES FOR 3-METER-WIDE X 4 METER LON</p> <p>G = 12SQUARE METER.2.#EXCAVATION FOR 2.2-METER-WIDE X 2-METER-DEEP X 4 METER LONG = 17.6CUBIC METER OF VOLUME AS SHOWN</p>	1	EA				

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412600363  
**DATE** : 25.02.2026  
**REQ No** : 1032600242  
**REQ TITLE** : URGENT REQUIREMENT:  
**DELIVERY LOCATION**  
**CLOSING DATE** : 03.03.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>IN THE BELOW            SKETCH.3.#THE EXCAVATION SHALL BE CONDUCTED IN STEPS AS SHOWN ABOVE.4.#THERE ARE THREE NG PIPELINE FOUNDATIONS LOCATED NEAR TO THE EXCAVATION AREA WHICH ARE HAVING DEPTH OF BOC AT -1.250 METER, HENCE DURING EXCAVATION BELOW THE DEPTH OF 1.25 METER THE SOIL AROUND NG FOUNDATION SHALL BE PROTECTED BY MEANS OF SHORING / STEEL PLATE JACKING SYSTEM. THE SUPPORTING SYSTEM SHALL BE ROBUST TO PREVENT ANY CHANCE OF SOIL COLLAPSE. THE EXCAVATION SHALL BE DONE IN SAFE MANNER AND PROTECTING NG FOUNDATIONS.5.#AS THE HEIGHT OF THE EXCAVATION IS AROUND 2 TO 2.2 METERS CONTRACTOR SHALL PROVIDE PROPER SLOPE/STEP CUTTING DURING EXCAVATION AND PROTECTION AGAINST COLLAPSING LOOSE SAND SHALL BE PROVIDED. IN EXISTING PLANT, APPROXIMATE HEIGHT OF 300 MM</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412600363  
**DATE** : 25.02.2026  
**REQ No** : 1032600242  
**REQ TITLE** : URGENT REQUIREMENT:  
**DELIVERY LOCATION**  
**CLOSING DATE** : 03.03.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>CONCRETE MIXTURE IS PLACED BELOW INTERLOCKTILES THIS SHALL BE REMOVED AND REINSTATED DURING BACKFILLING.6.#DN150 MM GRE PIPE LEAK RECTIFICATION WITH LAMINATION JOINT.7.#PIPELINE INLINE SERVICE TEST FOR WHICH DEWA WILL PROVIDE THE WATERAND CHARGE THE LINE WITH REQUIRED OPERATING PRESSURE.8.#IN CASE ANY LEAKAGE NOTICED DURING SERVICE TEST, CONTRACTOR SHALLREPAIR IMMEDIATELY AND IT IS COVERED UNDER THEIR WORK SCOPE.9.#UPON COMPLETION OF SERVICE TEST, BACK FILLING SHALL BE CARRIED OUTWITH THE REMOVED SAND. PROPER COMPACTION SHALL BE CARRIED OUT DURINGBACKFILLING.10.#REINSTATEMENT OF INTERLOCK TILES. CONTRACTOR SHALL ENSURE THAT NOINTERLOCKS ARE DAMAGED DURING REMOVAL AND REINSTATEMENT PROCESS, IN CASEIF ANY INTERLOCKS ARE DAMAGED IT SHALL BE REPLACED BY</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412600363  
**DATE** : 25.02.2026  
**REQ No** : 1032600242  
**REQ TITLE** : URGENT REQUIREMENT:  
**DELIVERY LOCATION**  
**CLOSING DATE** : 03.03.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>CONTRACTOR.B.#VARIABLE WORK SCOPE:AS THE EXACT LOCATION OF THE PIPELINE LEAK IS NOT IDENTIFIE</p> <p>D. IN CASE IFIT IS NOT FOUND INSIDE EXCAVATED AREA AS MENTIONED ABOVE THE ADDITIONALAREA WILL BE REQUIRED TO EXCAVATE BY PROTECTING THE NEARBY EXISTING NGPIPELINE FOUNDATIONS TO IDENTIFY PIPELINE LEAKAGE LOCATION. IN SUCH CASECONTRACTOR IS REQUIRED TO PROVIDE UNIT RATE OF EXCAVATION PER CUBICMETER CONSIDERING ABOVE WORK SCOPE AND SAFETY REQUIREMENT. THE PAYMENTWILL BE BASED ON ACTUAL MEASUREME NT OF THE QUANTITY AT SITE.CONTRACTOR TO PROVIDE THEIR QUOTE IN THE PRESCRIBED FORMAT BELOW.SERIAL NUMBER#WORK DESCRIPTION #UNIT OF MEASUREMENT#OFFERED PRICE1#PRICE SHALL BE QUOTED AS MENTIONED ABOVE IN A. FIX WORK SCOPEINCLUDING PRELIMINARY WORKS#LUMPSUM#2#PRICE</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412600363  
**DATE** : 25.02.2026  
**REQ No** : 1032600242  
**REQ TITLE** : URGENT REQUIREMENT:  
**DELIVERY LOCATION**  
**CLOSING DATE** : 03.03.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SHALL BE QUOTED AS MENTIONED ABOVE IN B. VARIABLE WORK SCOPE#PER CUBIC METER#SITE REQUIREMENTS:1.#SINCE ALL ACTIVITIES ARE CONDUCTED WITHIN THE NATURAL GAS STATION,WHICH IS CLASSIFIED AS A HAZARDOUS AREA, ALL NECESSARY PRECAUTIONSRELATED TO SUCH ENVIRONMENTS MUST BE STRICTLY FOLLOWED.2.#ALL EXCAVATION SHALL BE DONE ONLY MANUALLY AND WITH THEPLASTIC/FIBER SHOVEL.3.#CONDUCT DAILY SAFETY TOOLBOX TALKS FOR ALL PERSONNEL PRIOR TOCOMMENCING WORK.4.#ENSURE ALL WORKERS ARE EQUIPPED WITH THE NECESSARY PERSONALPROTECTIVE EQUIPMENT ( PPE) SUCH AS SAFETY HELMETS, REFLECTIVE VESTS,GLOVES, SAFETY BOOTS, AND GOGGLES.5.#PROTECT PIPELINES NEAR THE EXCAVATION WITH SCAFFOLDING AND SECUREBARRICADES TO PREVENT DAMAGE TO EXISTING UTILITIES.6.#MAINTAIN A FULLY STOCKED FIRST AID BOX AND ENSURE A</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412600363  
**DATE** : 25.02.2026  
**REQ No** : 1032600242  
**REQ TITLE** : URGENT REQUIREMENT:  
**DELIVERY LOCATION**  
**CLOSING DATE** : 03.03.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>FIRST AID ROOMS ACCESSIBLE ON-SITE AT ALL TIMES.7.#OBTAIN PRIOR PERMISSION FROM THE DEWA IN CHARGE BEFORE INITIATING ANY EXCAVATION OR REPAIR ACTIVITIES.8.#ASSIGN ONLY QUALIFIED, TRAINED, AND COMPETENT PERSONNEL TO PERFORM EXCAVATION.9.#IMPLEMENT ALL NECESSARY PRECAUTIONARY AND PROTECTIVE MEASURES PRIOR TO COMMENCING THE WORK.10.#BARRICADE THE WORKING AREA USING WARNING TAPES, SAFETY CONES, AND BARRIERS TO RESTRICT UNAUTHORIZED ACCESS.11.#VERIFY THAT ALL MATERIALS, TOOLS, AND EQUIPMENT USED ARE APPROVED, CERTIFIED, AND COMPLIANT WITH PROJECT SPECIFICATIONS.12.#CLEARLY MARK AND DEFINE THE EXCAVATION AREA AROUND THE DAMAGED PIPELINE. ENSURE THAT THE EXCAVATION WIDTH IS SUFFICIENT TO PROVIDE SAFE WORKING SPACE AND PROPER ACCESS FOR PIPE</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412600363  
**DATE** : 25.02.2026  
**REQ No** : 1032600242  
**REQ TITLE** : URGENT REQUIREMENT:  
**DELIVERY LOCATION**  
**CLOSING DATE** : 03.03.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>REPAIR.13.#PROVIDE ADEQUATE SHORING AND BRACING AS PER THE APPROVED DESIGN ANDENGINEER#S INSTRUCTIONS TO ENSURE EXCAVATION STABILITY.14.#UPON COMPLETION OF REPAIR ACTIVITIES, REMOVE ALL SHORING, B</p> <p>ACKFILLTHE EXCAVATION TO THE ORIGINAL GROUND LEVEL, COMPACT PROPERLY, AND CLEANTHE SITE THOROUGHLY.##GENERAL SAFETY PRECAUTIONS1.#ALL DEWA SAFETY &amp; ENVIRONMENT POLICY, RULES AND REGULATIONS SHALL BEFOLLOWED AT WORK SITE AND DEWA PREMISES DURING THE CONTRACT PERIOD</p> <p>. THECONTRACTOR'S WORK WILL FALL WITHIN THE PURVIEW OF SAFETY SURVEYSCONDUCTED REGULARLY BY THE DEWA SAFETY SECTION. ALL THEIR SAFETY REQUIREMENTS SHALL BE PROMPTLY MET.2.#THE CONTRACTOR SHALL CHECK THE CONDITION SUITABLE TO CARRY OUT THEWORK. CONDUCT SITE SURVEY A</p> <p>ND SAFETY INSPECTION TO ASSESS THE</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412600363  
**DATE** : 25.02.2026  
**REQ No** : 1032600242  
**REQ TITLE** : URGENT REQUIREMENT:  
**DELIVERY LOCATION**  
**CLOSING DATE** : 03.03.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>WORKINGENVIRONMENT, PROPER ISOLATION &amp; OTHER HAZARDS.3.#TOOL BOX TALK (TBT) SHALL BE GIVEN BY THE CONTRACTOR SUPERVISOR TOHIS STAFFS REGARDING THE NECESSARY STEPS TO BE TAKEN FOR SAFE EXECUTIONOF WORKS INCLUDING RISK ASSESSMENT CARRIED OUT PRIOR TO THE SUBMISSIONOF RISK ASSESSMENT SHEETS AND START OF WORK.4.#WELDING, FLAME HEATING OR CUTTING, GRINDING, PNEUMATIC CHIPPING,ETC. SHALL BE CARRIED OUT ONLY ON SPECIFIC CLEARANCE FROM DEWA THROUGH"HOT WORK PERMITS". THE HOT WORK PERMIT SHALL BE OBTAINED ON DAILYBASIS.5.#THE CONTRACTOR SHALL ENSURE THAT ADEQUATE FIRE PROTECTION EQUIPMENTAND MEN ARE AVAILABLE TO FIGHT ANY POSSIBLE HAZARDS. ALL DEWA RULES ANDREGULATIONS FOR HOT WORK PERMIT SHOULD BE STRICTLY FOLLOWED.6.#RISK ASSESSMENT (RA) SHALL BE UPDATED</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412600363  
**DATE** : 25.02.2026  
**REQ No** : 1032600242  
**REQ TITLE** : URGENT REQUIREMENT:  
**DELIVERY LOCATION**  
**CLOSING DATE** : 03.03.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>BASED ON THE PRESENTCONDITION,  ENVIRONMENT AND WORKING STAFFS ON A CASE  TO CASE BASIS. RASHOULD BE MORE SPECIFIC  BASED ON THE WORK  ON HAND AND  PREVAILINGENVIRONMENT.7.#PLANT  INSTALLATIONS, INSTRUMENTS, PIPING &amp;  ELECTRICAL CABLES IN THEWORK OR ADJACENT  AREA TO BE  ADEQUATELY PROTECTED AGAINST DAMAGE  WHILEEXECUTION OF THE CONTRACT  WORK.8.#WHILE WORKING THE CONTRACTOR  SHOULD BARRICADE THE AREA PR  EVENTINGMOVEMENT OF PLANT OPERATORS AND  MAINTENANCE PERSONNEL IN THE WORK  AREA.9.#ONLY NON-SPARKING TOOLS SHOULD BE  USED INCLUDING H  ACK SAW, KNIFE,HAMMER AND CHISEL ETC. INSIDE  NGPRS AND NG SYSTEM. THE DEWA SAFETY  RULESAND REGULATIONS PERTAINING TO NG AND  DFO SYST  EM SHOULD BE STRICTLYFOLLOWED AND  MONITORED BY THE SAFETY SUPERVISOR.10.#ALL</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412600363  
**DATE** : 25.02.2026  
**REQ No** : 1032600242  
**REQ TITLE** : URGENT REQUIREMENT:  
**DELIVERY LOCATION**  
**CLOSING DATE** : 03.03.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>EQUIPMENT LIKE RIGGING TOOLS, GRINDING MACHINES, DRILLI NGMACHINES, HAND TOOLS AND PRECISION TOOLS SHOULD HAVE VALID TESTCERTIFICATES FROM 3RD PARTY LICENSED CERTIFYING AGENCIES SHALL BEPR ODUCTION BY THE CONTRACTOR.11.#THE CONTRACTOR SHALL CARRY OUT RISK ANALYSIS FOR ALL HIS WORKS.THIS RISK ANALYSIS SHALL BE FROM SAFETY AS WELL AS OCCUPATIONAL HEALTHCONSIDERATIONS.12.#ALL SPECIAL TOOLS, RIGGING TOOLS, INSPECTION TOOLS, TEMPORARYPLATFORMS, LADDERS, HO SES ETC., SHALL BE INSPECTED AND TESTED BYAPPROVED AUTHORITIES AND THE CONTRACTOR SHALL SUBMIT TO DEWA ON DEMANDWITH NECESSARY CERTI FICATION BEFORE THEIR USE AT SITE.13.#THE TEMPORARY OFFICE/STORES OF THE CONTRACTOR IN THE PREMISES OFDEWA SHALL BE CONSTRUCTED OF N ON-FLAMMABLE MATERIAL. THE FACILITY</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412600363  
**DATE** : 25.02.2026  
**REQ No** : 1032600242  
**REQ TITLE** : URGENT REQUIREMENT:  
**DELIVERY LOCATION**  
**CLOSING DATE** : 03.03.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SHALL HAVE ADEQUATE NUMBER OF HEALTHY FIRE EXTINGUISHERS FOR USE DURING EMERGENCY SITUATIONS.14.#WELDING AND/OR OXY-ACYLINDER TROLLEYS, IF USED, AREA OF WELDING AND FLAME CUTTING SHALL HAVE ADEQUATE NUMBER OF HEALTHY FIRE EXTINGUISHERS, NON-ASBESTOS FLAME/HEAT BLANKETS. CYLINDERS TO BE CLOSED WHILE NOT IN USE.15.#THE AREA OF WORK SHALL BE KEPT CLEAN AT ALL TIMES BEFORE, DURING AND AFTER T						
2		ITEM-00001	REMOVAL OF INTERLOCK, EXCAVATION, EXPOSING GRE FIRE WATER PIPELINE, 150MM DIAMETER GRE PIPE LEAK RECTIFICATION, SERVICE PRESSURE TEST POST LEAK RECTIFICATION BY NORMALIZING THE SYSTEM, BACK FILLING, COMPACTION, INTERLOCK TILES REFIXING AND REINSTATEMENT OF AREA INSIDE NATURAL GAS STATION AT H-STATION, PHASE-1, AL-AWEER. SCOPE OF WORK: CONTRACTOR TO CONSIDER FOLLOWING WORK	4	CBM				

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412600363  
**DATE** : 25.02.2026  
**REQ No** : 1032600242  
**REQ TITLE** : URGENT REQUIREMENT:  
**DELIVERY LOCATION**  
**CLOSING DATE** : 03.03.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SCOPE,PRELIMINARY PREPARATORY WORKS:1.#EXCAVATE A TRIAL PIT OF 80 CM WIDTH TO LOCATE THE LEAK AREA ANDFULLY EXPOSE THE EXISTING GRE PIPELINE, FOLLOWING THE ENGINEER#SINSTRUCTIONS IN THE CENTRALLY MARKED RED ZONE.A.#FIX WORK</p> <p>SCOPE:1.#REMOVAL OF INTERLOCK TILES FOR 3-METER-WIDE X 4 METER LONG = 12 SQUARE METER.2.#EXCAVATION FOR 2.2-METER-WIDE X 2-METER-DEEP X 4 METER LONG = 17.6CUBIC METER OF VOLUME AS SHOWN IN THE BELOW SKETCH.3.#THE EXCAVATION SHALL BE CONDUCTED IN STEPS AS SHOWN ABOVE.4.#THERE ARE THREE NG PIPELINE FOUNDATIONS LOCATED NEAR TO THE EXCAVATION AREA WHICH ARE HAVING DEPTH OF BOC AT -1.250 METER, HENCE DURING EXCAVATION BELOW THE DEPTH OF 1.25 METER THE SOIL AROUND NG FOUNDATION SHALL BE PROTECTED BY MEANS OF SHORING / STEEL PLATE JACKING SYSTEM. THE</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412600363  
**DATE** : 25.02.2026  
**REQ No** : 1032600242  
**REQ TITLE** : URGENT REQUIREMENT:  
**DELIVERY LOCATION**  
**CLOSING DATE** : 03.03.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SUPPORTING SYSTEM SHALL BE ROBUST TO PREVENT ANY CHANCE OF SOIL COLLAPSE. THE EXCAVATION SHALL BE DONE IN SAFE MANNER AND PROTECTING NG FOUNDATIONS.5.#AS THE HEIGHT OF THE EXCAVATION IS AROUND 2 TO 2.2 METERS CONTRACTOR SHALL PROVIDE PROPER SLOPE/STEP CUTTING DURING EXCAVATION AND PROTECTION AGAINST COLLAPSING LOOSE SAND SHALL BE PROVIDED. IN EXISTING PLANT, APPROXIMATE HEIGHT OF 300 MM CONCRETE MIXTURE IS PLACED BELOW INTERLOCK TILES THIS SHALL BE REMOVED AND REINSTATED DURING BACKFILLING.6.#DN150 MM GRE PIPE LEAK RECTIFICATION WITH LAMINATION JOINT.7.#PIPELINE INLINE SERVICE TEST FOR WHICH DEWA WILL PROVIDE THE WATER AND CHARGE THE LINE WITH REQUIRED OPERATING PRESSURE.8.#IN CASE ANY LEAKAGE NOTICED DURING SERVICE TEST, CONTRACTOR SHALL REPAIR</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412600363  
**DATE** : 25.02.2026  
**REQ No** : 1032600242  
**REQ TITLE** : URGENT REQUIREMENT:  
**DELIVERY LOCATION**  
**CLOSING DATE** : 03.03.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>IMMEDIATELY AND IT IS COVERED UNDER THEIR WORK SCOPE.9.#UPON COMPLETION OF SERVICE TEST, BACK FILLING SHALL BE CARRIED OUT WITH THE REMOVED SAND. PROPER COMPACTION SHALL BE CARRIED OUT DURING BACK FILLING.10.#REINSTATEMENT OF INTERLOCK TILES. CONTRACTOR SHALL ENSURE THAT INTERLOCKS ARE DAMAGED DURING REMOVAL AND REINSTATEMENT PROCESS, IN CASE IF ANY INTERLOCKS ARE DAMAGED IT SHALL BE REPLACED BY CONTRACTOR.B.#VARIABLE WORK SCOPE: AS THE EXACT LOCATION OF THE PIPELINE LEAK IS NOT IDENTIFIED. D. IN CASE IF IT IS NOT FOUND INSIDE EXCAVATED AREA AS MENTIONED ABOVE THE ADDITIONAL AREA WILL BE REQUIRED TO EXCAVATE BY PROTECTING THE NEARBY EXISTING NG PIPELINE FOUNDATIONS TO IDENTIFY PIPELINE LEAKAGE LOCATION. IN SUCH CASE CONTRACTOR IS REQUIRED TO PROVIDE UNIT</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412600363  
**DATE** : 25.02.2026  
**REQ No** : 1032600242  
**REQ TITLE** : URGENT REQUIREMENT:  
**DELIVERY LOCATION**  
**CLOSING DATE** : 03.03.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>RATE OF EXCAVATION PER CUBICMETER CONSIDERING ABOVE WORK SCOPE AND SAFETY REQUIREMENT. THE PAYMENTWILL BE BASED ON ACTUAL MEASUREME            NT OF THE QUANTITY AT SITE.CONTRACTOR TO PROVIDE THEIR QUOTE IN THE PRESCRIBED FORMAT BELOW.SERIAL NUMBER#WORK DESCRIPTION #UNIT OF MEASUREMENT#OFFERED PRICE1#PRICE SHALL BE QUOTED AS MENTIONED ABOVE IN A. FIX WORK SCOPEINCLUDING PRELIMINARY WORKS#LUMPSUM#2#PRICE SHALL BE QUOTED AS MENTIONED ABOVE IN B. VARIABLE WORK SCOPE#PER CUBIC METER#SITE REQUIREMENTS:1.#SINCE ALL ACTIVITIES ARE CONDUCTED WITHIN THE NATURAL GAS STATION,WHICH IS CLASSIFIED AS A HAZARDOUS AREA, ALL NECESSARY PRECAUTIONSRELATED TO SUCH ENVIRONMENTS MUST BE STRICTLY FOLLOWED.2.#ALL EXCAVATION SHALL BE DONE ONLY MANUALLY AND WITH THEPLASTIC/FIBER SHOVEL.3.#CONDUCT DAILY</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412600363  
**DATE** : 25.02.2026  
**REQ No** : 1032600242  
**REQ TITLE** : URGENT REQUIREMENT:  
**DELIVERY LOCATION**  
**CLOSING DATE** : 03.03.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SAFETY TOOLBOX  TALKS FOR ALL PERSONNEL PRIOR  TO COMMENCING WORK.4.#ENSURE ALL WORKERS  ARE EQUIPPED WITH THE NECESSARY  PERSONAL PROTECTIVE EQUIPMENT ( PPE)  SUCH AS SAFETY HELMETS, REFLECTIVE  VESTS,GLOVES, SAFETY BOOTS, AND  GOGGLES.5.#PROTECT PIPELINES NEAR THE  EXCAVATION WITH SCAFFOLDING AND  SECURE BARRICADES TO PREVENT  DAMAGE TO EXISTING UTILITIES.6.#MAINTAIN  A FULLY STOCKED FIRST AID BOX AND  ENSURE A FIRST AID ROOM IS  ACCESSIBLE ON-SITE AT ALL TIMES.7.#OBTAIN  PRIOR PERMISSION FROM THE DEWA IN  CHARGE BEFORE INITIATING ANY  EXCAVATION OR REPAIR ACTIVITIES.8.#ASSIGN  ONLY QUALIFIED, TRAINED, AND  COMPETENT PERSONNEL TO PERFORM  EXCAVATION.9.#IMPLEMENT ALL  NECESSARY PRECAUTIONARY AND  PROTECTIVE MEASURES PRIOR TO  COMMENCING THE WORK.10.#BARRICADE THE</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412600363  
**DATE** : 25.02.2026  
**REQ No** : 1032600242  
**REQ TITLE** : URGENT REQUIREMENT:  
**DELIVERY LOCATION**  
**CLOSING DATE** : 03.03.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>WORKING AREA USING WARNING TAPES, SAFETY CONES, ANDBARRIERS TO RESTRICT UNAUTHORIZED ACCESS.11.#VERIFY THAT ALL MATERIALS, TOOLS, AND EQUIPMENT USED ARE APPROVED,CERTIFIED, AND COMPLIANT WITH PR</p> <p>OJECT SPECIFICATIONS.12.#CLEARLY MARK AND DEFINE THE EXCAVATION AREA AROUND THE DAMAGEDPIPELINE. ENSURE THAT THE EXCAVATION WIDTH IS SUFFICIENT TO PROVIDE SAFEWORKING SPACE AND PROPER ACCESS FOR PIPE REPAIR.13.#PROVIDE ADEQUATE SHORING AND BRACING AS PER THE APPROVED DESIGN ANDENGINEER#S INSTRUCTIONS TO ENSURE EXCAVATION STABILITY.14.#UPON COMPLETION OF REPAIR ACTIVITIES, REMOVE ALL SHORING, B</p> <p>ACKFILLTHE EXCAVATION TO THE ORIGINAL GROUND LEVEL, COMPACT PROPERLY, AND CLEANTHE SITE THOROUGHLY.##GENERAL SAFETY PRECAUTIONS1.#ALL DEWA SAFETY &amp; ENVIRONMENT POLICY, RULES</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412600363  
**DATE** : 25.02.2026  
**REQ No** : 1032600242  
**REQ TITLE** : URGENT REQUIREMENT:  
**DELIVERY LOCATION**  
**CLOSING DATE** : 03.03.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>AND REGULATIONS SHALL BE FOLLOWED AT WORK SITE AND DEWA PREMISES DURING THE CONTRACT PERIOD . THE CONTRACTOR'S WORK WILL FALL WITHIN THE PURVIEW OF SAFETY SURVEYS CONDUCTED REGULARLY BY THE DEWA SAFETY SECTION. ALL THEIR SAFETY REQUIREMENTS SHALL BE PROMPTLY MET. 2.#THE CONTRACTOR SHALL CHECK THE CONDITION SUITABLE TO CARRY OUT THE WORK. CONDUCT SITE SURVEY AND SAFETY INSPECTION TO ASSESS THE WORKING ENVIRONMENT, PROPER ISOLATION &amp; OTHER HAZARDS. 3.#TOOL BOX TALK (TBT) SHALL BE GIVEN BY THE CONTRACTOR SUPERVISOR TO HIS STAFFS REGARDING THE NECESSARY STEPS TO BE TAKEN FOR SAFE EXECUTION OF WORKS INCLUDING RISK ASSESSMENT CARRIED OUT PRIOR TO THE SUBMISSION OF RISK ASSESSMENT SHEETS AND START OF WORK. 4.#WELDING, FLAME HEATING OR CUTTING, GRINDING, PNEUMA</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412600363  
**DATE** : 25.02.2026  
**REQ No** : 1032600242  
**REQ TITLE** : URGENT REQUIREMENT:  
**DELIVERY LOCATION**  
**CLOSING DATE** : 03.03.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>TIC CHIPPING,ETC. SHALL BE CARRIED OUT ONLY ON SPECIFIC CLEARANCE FROM DEWA THROUGH"HOT WORK PERMITS". THE HOT WORK PERMIT SHALL BE OBTAINED ON DAILYBASIS.5.#THE CONTRACTOR SHALL ENSURE THAT ADEQUATE FIRE PROTECTION EQUIPMENTAND MEN ARE AVAILABLE TO FIGHT ANY POSSIBLE HAZARDS. ALL DEWA RULES ANDREGULATIONS FOR HOT WORK PERMIT SHOULD BE STRICTLY FOLLOWED.6.#RISK ASSESSMENT (RA) SHALL BE UPDATED BASED ON THE PRESENTCONDITION, ENVIRONMENT AND WORKING STAFFS ON A CASE TO CASE BASIS. RASHOULD BE MORE SPECIFIC BASED ON THE WORK ON HAND AND PREVAILINGENVIRONMENT.7.#PLANT INSTALLATIONS, INSTRUMENTS, PIPING &amp; ELECTRICAL CABLES IN THEWORK OR ADJACENT AREA TO BE ADEQUATELY PROTECTED AGAINST DAMAGE WHILEEXECUTION OF THE CONTRACT</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412600363  
**DATE** : 25.02.2026  
**REQ No** : 1032600242  
**REQ TITLE** : URGENT REQUIREMENT:  
**DELIVERY LOCATION**  
**CLOSING DATE** : 03.03.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>WORK.8.#WHILE WORKING THE CONTRACTOR SHOULD BARRICADE THE AREA PR EVENTINGMOVEMENT OF PLANT OPERATORS AND MAINTENANCE PERSONNEL IN THE WORK AREA.9.#ONLY NON-SPARKING TOOLS SHOULD BE USED INCLUDING H ACK SAW, KNIFE,HAMMER AND CHISEL ETC. INSIDE NGPRS AND NG SYSTEM. THE DEWA SAFETY RULESAND REGULATIONS PERTAINING TO NG AND DFO SYST EM SHOULD BE STRICTLYFOLLOWED AND MONITORED BY THE SAFETY SUPERVISOR.10.#ALL EQUIPMENT LIKE RIGGING TOOLS, GRINDING MACHINES, DRILLI NGMACHINES, HAND TOOLS AND PRECISION TOOLS SHOULD HAVE VALID TESTCERTIFICATES FROM 3RD PARTY LICENSED CERTIFYING AGENCIES SHALL BEPR ODUCE BY THE CONTRACTOR.11.#THE CONTRACTOR SHALL CARRY OUT RISK ANALYSIS FOR ALL HIS WORKS.THIS RISK ANALYSIS SHALL BE FROM SAFETY AS WELL AS OCCUPATIONAL</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412600363  
**DATE** : 25.02.2026  
**REQ No** : 1032600242  
**REQ TITLE** : URGENT REQUIREMENT:  
**DELIVERY LOCATION**  
**CLOSING DATE** : 03.03.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>HEALTHCONSIDERATIONS.12.#ALL SPECIAL TOOLS, RIGGING TOOLS, INSPECTION TOOLS, TEMPORARYPLATFORMS, LADDERS, HOSES ETC., SHALL BE INSPECTED AND TESTED BYAPPROVED AUTHORITIES AND THE CONTRACTOR SHALL SUBMIT TO DEWA ON DEMANDWITH NECESSARY CERTIFICATION BEFORE THEIR USE AT SITE.13.#THE TEMPORARY OFFICE/STORES OF THE CONTRACTOR IN THE PREMISES OFDEWA SHALL BE CONSTRUCTED OF NON-FLAMMABLE MATERIAL. THE FACILITY SHALLHAVE ADEQUATE NUMBER OF HEALTHY FIRE EXTINGUISHERS FOR USE DURINGEMERGENCY SITUATIONS.14.#WELDING AND/OR OXY-ACY CYLINDER TROLLEYS, IF USED, AREA OF WELDINGAND FLAME CUTTING SHALL HAVE ADEQUATE NUMBER OF HEALTHY FIREEXTINGUISHERS, NON-ASBESTOS FLAME/HEAT BLANKETS. CYLINDERS TO BE CLOSEDWHILE NOT IN USE.15.#THE AREA OF WORK SHALL BE KEPT CLEAN AT ALL TIM</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412600363  
**DATE** : 25.02.2026  
**REQ No** : 1032600242  
**REQ TITLE** : URGENT REQUIREMENT:  
**DELIVERY LOCATION**  
**CLOSING DATE** : 03.03.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ES BEFORE, DURING AND AFTER T						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

### **SPECIAL NOTES / INSTRUCTIONS:**

URGENT REQUIREMENT: UNDERGROUND FIRE WATER PIPELINE LEAK RECTIFICATION INSIDE NATURAL GAS STATION; PHASE 1; AL AWEER. for more information and details please contact: zamir.alware zamir.alware@dewa.gov.ae 04-81-40304 +971509152946

### **STANDARD TERMS & CONDITIONS**

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.
- 6) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer.

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412600363  
**DATE** : 25.02.2026  
**REQ No** : 1032600242  
**REQ TITLE** : URGENT REQUIREMENT:  
**DELIVERY LOCATION**  
**CLOSING DATE** : 03.03.2026  
**CLOSING TIME** : 10:00:00

If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements  
The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

**SUPPLIER'S REMARKS :**

**SUPPLIER'S SIGNATURE AND STAMP**

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412600363  
**DATE** : 25.02.2026  
**REQ No** : 1032600242  
**REQ TITLE** : URGENT REQUIREMENT:  
**DELIVERY LOCATION**  
**CLOSING DATE** : 03.03.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	<p>REMOVAL OF INTERLOCK, EXCAVATION, EXPOSING GRE FIRE WATER PIPELINE, 150MM DIAMETER GRE PIPE LEAK RECTIFICATION, SERVICE PRESSURE TES</p> <p>T POST LEAKRECTIFICATION BY NORMALIZING THE SYSTEM, BACK FILLING, COMPACTION, INTERLOCK TILES REFIXING AND REINSTATEMENT OF AREA INSI</p> <p>DE NATURAL GASSTATION AT H-STATION, PHASE-1, AL-AWEER.SCOPE OF WORK:CONTRACTOR TO CONSIDER FOLLOWING WORK</p> <p>SCOPE,PRELIMINARY PREPARAT</p> <p>ORY WORKS:1.#EXCAVATE A TRIAL PIT OF 80 CM WIDTH TO LOCATE THE LEAK AREA ANDFULLY EXPOSE THE EXISTING GRE PIPELINE, FOLLOWING THE EN</p> <p>GINEER#SINSTRUCTIONS IN THE CENTRALLY MARKED RED ZONE.A.#FIX WORK</p> <p>SCOPE:1.#REMOVAL OF INTERLOCK TILES FOR 3-METER-WIDE X 4 METER LON</p> <p>G = 12SQUARE METER.2.#EXCAVATION FOR 2.2-METER-WIDE X 2-METER-DEEP X 4 METER LONG = 17.6CUBIC METER OF VOLUME AS SHOWN</p>	1	EA				

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412600363  
**DATE** : 25.02.2026  
**REQ No** : 1032600242  
**REQ TITLE** : URGENT REQUIREMENT:  
**DELIVERY LOCATION**  
**CLOSING DATE** : 03.03.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>IN THE BELOW            SKETCH.3.#THE EXCAVATION SHALL BE CONDUCTED IN STEPS AS SHOWN ABOVE.4.#THERE ARE THREE NG PIPELINE FOUNDATIONS LOCATED NEAR TO THE EXCAVATION AREA WHICH ARE HAVING DEPTH OF BOC AT -1.250 METER, HENCE DURING EXCAVATION BELOW THE DEPTH OF 1.25 METER THE SOIL AROUND NG FOUNDATION SHALL BE PROTECTED BY MEANS OF SHORING / STEEL PLATE JACKING SYSTEM. THE SUPPORTING SYSTEM SHALL BE ROBUST TO PREVENT ANY CHANCE OF SOIL COLLAPSE. THE EXCAVATION SHALL BE DONE IN SAFE MANNER AND PROTECTING NG FOUNDATIONS.5.#AS THE HEIGHT OF THE EXCAVATION IS AROUND 2 TO 2.2 METERS CONTRACTOR SHALL PROVIDE PROPER SLOPE/STEP CUTTING DURING EXCAVATION AND PROTECTION AGAINST COLLAPSING LOOSE SAND SHALL BE PROVIDED. IN EXISTING PLANT, APPROXIMATE HEIGHT OF 300 MM</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412600363  
**DATE** : 25.02.2026  
**REQ No** : 1032600242  
**REQ TITLE** : URGENT REQUIREMENT:  
**DELIVERY LOCATION**  
**CLOSING DATE** : 03.03.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>CONCRETE MIXTURE IS PLACED BELOW INTERLOCKTILES THIS SHALL BE REMOVED AND REINSTATED DURING BACKFILLING.6.#DN150 MM GRE PIPE LEAK RECTIFICATION WITH LAMINATION JOINT.7.#PIPELINE INLINE SERVICE TEST FOR WHICH DEWA WILL PROVIDE THE WATERAND CHARGE THE LINE WITH REQUIRED OPERATING PRESSURE.8.#IN CASE ANY LEAKAGE NOTICED DURING SERVICE TEST, CONTRACTOR SHALLREPAIR IMMEDIATELY AND IT IS COVERED UNDER THEIR WORK SCOPE.9.#UPON COMPLETION OF SERVICE TEST, BACK FILLING SHALL BE CARRIED OUTWITH THE REMOVED SAND. PROPER COMPACTION SHALL BE CARRIED OUT DURINGBACKFILLING.10.#REINSTATEMENT OF INTERLOCK TILES. CONTRACTOR SHALL ENSURE THAT NOINTERLOCKS ARE DAMAGED DURING REMOVAL AND REINSTATEMENT PROCESS, IN CASEIF ANY INTERLOCKS ARE DAMAGED IT SHALL BE REPLACED BY</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412600363  
**DATE** : 25.02.2026  
**REQ No** : 1032600242  
**REQ TITLE** : URGENT REQUIREMENT:  
**DELIVERY LOCATION**  
**CLOSING DATE** : 03.03.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>CONTRACTOR.B.#VARIABLE WORK SCOPE:AS THE EXACT LOCATION OF THE PIPELINE LEAK IS NOT IDENTIFIED</p> <p>D. IN CASE IF IT IS NOT FOUND INSIDE EXCAVATED AREA AS MENTIONED ABOVE THE ADDITIONAL AREA WILL BE REQUIRED TO EXCAVATE BY PROTECTING THE NEARBY EXISTING NG PIPELINE FOUNDATIONS TO IDENTIFY PIPELINE LEAKAGE LOCATION. IN SUCH CASE CONTRACTOR IS REQUIRED TO PROVIDE UNIT RATE OF EXCAVATION PER CUBIC METER CONSIDERING ABOVE WORK SCOPE AND SAFETY REQUIREMENT. THE PAYMENT WILL BE BASED ON ACTUAL MEASUREMENT OF THE QUANTITY AT SITE. CONTRACTOR TO PROVIDE THEIR QUOTE IN THE PRESCRIBED FORMAT BELOW. SERIAL NUMBER#WORK DESCRIPTION #UNIT OF MEASUREMENT#OFFERED PRICE1#PRICE SHALL BE QUOTED AS MENTIONED ABOVE IN A. FIX WORK SCOPE INCLUDING PRELIMINARY WORKS#LUMPSUM#2#PRICE</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412600363  
**DATE** : 25.02.2026  
**REQ No** : 1032600242  
**REQ TITLE** : URGENT REQUIREMENT:  
**DELIVERY LOCATION**  
**CLOSING DATE** : 03.03.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SHALL BE QUOTED AS MENTIONED ABOVE IN B. VARIABLE WORK SCOPE#PER CUBIC METER#SITE REQUIREMENTS:1.#SINCE ALL ACTIVITIES ARE CONDUCTED WITHIN THE NATURAL GAS STATION,WHICH IS CLASSIFIED AS A HAZARDOUS AREA, ALL NECESSARY PRECAUTIONSRELATED TO SUCH ENVIRONMENTS MUST BE STRICTLY FOLLOWED.2.#ALL EXCAVATION SHALL BE DONE ONLY MANUALLY AND WITH THEPLASTIC/FIBER SHOVEL.3.#CONDUCT DAILY SAFETY TOOLBOX TALKS FOR ALL PERSONNEL PRIOR TOCOMMENCING WORK.4.#ENSURE ALL WORKERS ARE EQUIPPED WITH THE NECESSARY PERSONALPROTECTIVE EQUIPMENT ( PPE) SUCH AS SAFETY HELMETS, REFLECTIVE VESTS,GLOVES, SAFETY BOOTS, AND GOGGLES.5.#PROTECT PIPELINES NEAR THE EXCAVATION WITH SCAFFOLDING AND SECUREBARRICADES TO PREVENT DAMAGE TO EXISTING UTILITIES.6.#MAINTAIN A FULLY STOCKED FIRST AID BOX AND ENSURE A</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412600363  
**DATE** : 25.02.2026  
**REQ No** : 1032600242  
**REQ TITLE** : URGENT REQUIREMENT:  
**DELIVERY LOCATION**  
**CLOSING DATE** : 03.03.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>FIRST AID ROOMS ACCESSIBLE ON-SITE AT ALL TIMES.7.#OBTAIN PRIOR PERMISSION FROM THE DEWA IN CHARGE BEFORE INITIATING ANY EXCAVATION OR REPAIR ACTIVITIES.8.#ASSIGN ONLY QUALIFIED, TRAINED, AND COMPETENT PERSONNEL TO PERFORM EXCAVATION.9.#IMPLEMENT ALL NECESSARY PRECAUTIONARY AND PROTECTIVE MEASURES PRIOR TO COMMENCING THE WORK.10.#BARRICADE THE WORKING AREA USING WARNING TAPES, SAFETY CONES, AND BARRIERS TO RESTRICT UNAUTHORIZED ACCESS.11.#VERIFY THAT ALL MATERIALS, TOOLS, AND EQUIPMENT USED ARE APPROVED, CERTIFIED, AND COMPLIANT WITH PROJECT SPECIFICATIONS.12.#CLEARLY MARK AND DEFINE THE EXCAVATION AREA AROUND THE DAMAGED PIPELINE. ENSURE THAT THE EXCAVATION WIDTH IS SUFFICIENT TO PROVIDE SAFE WORKING SPACE AND PROPER ACCESS FOR PIPE</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412600363  
**DATE** : 25.02.2026  
**REQ No** : 1032600242  
**REQ TITLE** : URGENT REQUIREMENT:  
**DELIVERY LOCATION**  
**CLOSING DATE** : 03.03.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>REPAIR.13.#PROVIDE ADEQUATE SHORING AND BRACING AS PER THE APPROVED DESIGN ANDENGINEER#S INSTRUCTIONS TO ENSURE EXCAVATION STABILITY.14.#UPON COMPLETION OF REPAIR ACTIVITIES, REMOVE ALL SHORING, B</p> <p>ACKFILLTHE EXCAVATION TO THE ORIGINAL GROUND LEVEL, COMPACT PROPERLY, AND CLEANTHE SITE THOROUGHLY.##GENERAL SAFETY PRECAUTIONS1.#ALL DEWA SAFETY &amp; ENVIRONMENT POLICY, RULES AND REGULATIONS SHALL BE FOLLOWED AT WORK SITE AND DEWA PREMISES DURING THE CONTRACT PERIOD</p> <p>. THECONTRACTOR'S WORK WILL FALL WITHIN THE PURVIEW OF SAFETY SURVEYS CONDUCTED REGULARLY BY THE DEWA SAFETY SECTION. ALL THEIR SAFETY REQUIREMENTS SHALL BE PROMPTLY MET.2.#THE CONTRACTOR SHALL CHECK THE CONDITION SUITABLE TO CARRY OUT THEWORK. CONDUCT SITE SURVEY A</p> <p>ND SAFETY INSPECTION TO ASSESS THE</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412600363  
**DATE** : 25.02.2026  
**REQ No** : 1032600242  
**REQ TITLE** : URGENT REQUIREMENT:  
**DELIVERY LOCATION**  
**CLOSING DATE** : 03.03.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>WORKINGENVIRONMENT, PROPER ISOLATION &amp; OTHER HAZARDS.3.#TOOL BOX TALK (TBT) SHALL BE GIVEN BY THE CONTRACTOR SUPERVISOR TOHIS STAFFS REGARDING THE NECESSARY STEPS TO BE TAKEN FOR SAFE EXECUTIONOF WORKS INCLUDING RISK ASSESSMENT CARRIED OUT PRIOR TO THE SUBMISSIONOF RISK ASSESSMENT SHEETS AND START OF WORK.4.#WELDING, FLAME HEATING OR CUTTING, GRINDING, PNEUMATIC CHIPPING,ETC. SHALL BE CARRIED OUT ONLY ON SPECIFIC CLEARANCE FROM DEWA THROUGH"HOT WORK PERMITS". THE HOT WORK PERMIT SHALL BE OBTAINED ON DAILYBASIS.5.#THE CONTRACTOR SHALL ENSURE THAT ADEQUATE FIRE PROTECTION EQUIPMENTAND MEN ARE AVAILABLE TO FIGHT ANY POSSIBLE HAZARDS. ALL DEWA RULES ANDREGULATIONS FOR HOT WORK PERMIT SHOULD BE STRICTLY FOLLOWED.6.#RISK ASSESSMENT (RA) SHALL BE UPDATED</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412600363  
**DATE** : 25.02.2026  
**REQ No** : 1032600242  
**REQ TITLE** : URGENT REQUIREMENT:  
**DELIVERY LOCATION**  
**CLOSING DATE** : 03.03.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>BASED ON THE PRESENTCONDITION,  ENVIRONMENT AND WORKING STAFFS ON A CASE  TO CASE BASIS. RASHOULD BE MORE SPECIFIC  BASED ON THE WORK  ON HAND AND  PREVAILINGENVIRONMENT.7.#PLANT  INSTALLATIONS, INSTRUMENTS, PIPING &amp;  ELECTRICAL CABLES IN THEWORK OR ADJACENT  AREA TO BE  ADEQUATELY PROTECTED AGAINST DAMAGE  WHILEEXECUTION OF THE CONTRACT  WORK.8.#WHILE WORKING THE CONTRACTOR  SHOULD BARRICADE THE AREA PR  EVENTINGMOVEMENT OF PLANT OPERATORS AND  MAINTENANCE PERSONNEL IN THE WORK  AREA.9.#ONLY NON-SPARKING TOOLS SHOULD BE  USED INCLUDING H  ACK SAW, KNIFE,HAMMER AND CHISEL ETC. INSIDE  NGPRS AND NG SYSTEM. THE DEWA SAFETY  RULESAND REGULATIONS PERTAINING TO NG AND  DFO SYST  EM SHOULD BE STRICTLYFOLLOWED AND  MONITORED BY THE SAFETY SUPERVISOR.10.#ALL</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412600363  
**DATE** : 25.02.2026  
**REQ No** : 1032600242  
**REQ TITLE** : URGENT REQUIREMENT:  
**DELIVERY LOCATION**  
**CLOSING DATE** : 03.03.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>EQUIPMENT LIKE RIGGING TOOLS, GRINDING MACHINES, DRILLI NGMACHINES, HAND TOOLS AND PRECISION TOOLS SHOULD HAVE VALID TESTCERTIFICATES FROM 3RD PARTY LICENSED CERTIFYING AGENCIES SHALL BEPR ODUCTION BY THE CONTRACTOR.11.#THE CONTRACTOR SHALL CARRY OUT RISK ANALYSIS FOR ALL HIS WORKS.THIS RISK ANALYSIS SHALL BE FROM SAFETY AS WELL AS OCCUPATIONAL HEALTHCONSIDERATIONS.12.#ALL SPECIAL TOOLS, RIGGING TOOLS, INSPECTION TOOLS, TEMPORARYPLATFORMS, LADDERS, HO SES ETC., SHALL BE INSPECTED AND TESTED BYAPPROVED AUTHORITIES AND THE CONTRACTOR SHALL SUBMIT TO DEWA ON DEMANDWITH NECESSARY CERTI FICATION BEFORE THEIR USE AT SITE.13.#THE TEMPORARY OFFICE/STORES OF THE CONTRACTOR IN THE PREMISES OFDEWA SHALL BE CONSTRUCTED OF N ON-FLAMMABLE MATERIAL. THE FACILITY</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412600363  
**DATE** : 25.02.2026  
**REQ No** : 1032600242  
**REQ TITLE** : URGENT REQUIREMENT:  
**DELIVERY LOCATION**  
**CLOSING DATE** : 03.03.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SHALL HAVE ADEQUATE NUMBER OF HEALTHY FIRE EXTINGUISHERS FOR USE DURING EMERGENCY SITUATIONS. 14.#WELDING AND/OR OXY-ACYLINDER TROLLEYS, IF USED, AREA OF WELDING AND FLAME CUTTING SHALL HAVE ADEQUATE NUMBER OF HEALTHY FIRE EXTINGUISHERS, NON-ASBESTOS FLAME/HEAT BLANKETS. CYLINDERS TO BE CLOSED WHILE NOT IN USE. 15.#THE AREA OF WORK SHALL BE KEPT CLEAN AT ALL TIMES BEFORE, DURING AND AFTER T						
2		ITEM-00001	REMOVAL OF INTERLOCK, EXCAVATION, EXPOSING GRE FIRE WATER PIPELINE, 150MM DIAMETER GRE PIPE LEAK RECTIFICATION, SERVICE PRESSURE TEST POST LEAK RECTIFICATION BY NORMALIZING THE SYSTEM, BACK FILLING, COMPACTION, INTERLOCK TILES REFIXING AND REINSTATEMENT OF AREA INSIDE NATURAL GAS STATION AT H-STATION, PHASE-1, AL-AWEER. SCOPE OF WORK: CONTRACTOR TO CONSIDER FOLLOWING WORK	4	CBM				

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412600363  
**DATE** : 25.02.2026  
**REQ No** : 1032600242  
**REQ TITLE** : URGENT REQUIREMENT:  
**DELIVERY LOCATION**  
**CLOSING DATE** : 03.03.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SCOPE,PRELIMINARY PREPARATORY WORKS:1.#EXCAVATE A TRIAL PIT OF 80 CM WIDTH TO LOCATE THE LEAK AREA ANDFULLY EXPOSE THE EXISTING GRE PIPELINE, FOLLOWING THE ENGINEER#SINSTRUCTIONS IN THE CENTRALLY MARKED RED ZONE.A.#FIX WORK</p> <p>SCOPE:1.#REMOVAL OF INTERLOCK TILES FOR 3-METER-WIDE X 4 METER LONG = 12 SQUARE METER.2.#EXCAVATION FOR 2.2-METER-WIDE X 2-METER-DEEP X 4 METER LONG = 17.6CUBIC METER OF VOLUME AS SHOWN IN THE BELOW SKETCH.3.#THE EXCAVATION SHALL BE CONDUCTED IN STEPS AS SHOWN ABOVE.4.#THERE ARE THREE NG PIPELINE FOUNDATIONS LOCATED NEAR TO THE EXCAVATION AREA WHICH ARE HAVING DEPTH OF BOC AT -1.250 METER, HENCE DURING EXCAVATION BELOW THE DEPTH OF 1.25 METER THE SOIL AROUND NG FOUNDATION SHALL BE PROTECTED BY MEANS OF SHORING / STEEL PLATE JACKING SYSTEM. THE</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412600363  
**DATE** : 25.02.2026  
**REQ No** : 1032600242  
**REQ TITLE** : URGENT REQUIREMENT:  
**DELIVERY LOCATION**  
**CLOSING DATE** : 03.03.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SUPPORTING SYSTEM SHALL BE ROBUST TO PREVENT ANY CHANCE OF SOIL COLLAPSE. THE EXCAVATION SHALL BE DONE IN SAFE MANNER AND PROTECTING NG FOUNDATIONS.5.#AS THE HEIGHT OF THE EXCAVATION IS AROUND 2 TO 2.2 METERS CONTRACTOR SHALL PROVIDE PROPER SLOPE/STEP CUTTING DURING EXCAVATION AND PROTECTION AGAINST COLLAPSING LOOSE SAND SHALL BE PROVIDED. IN EXISTING PLANT, APPROXIMATE HEIGHT OF 300 MM CONCRETE MIXTURE IS PLACED BELOW INTERLOCK TILES THIS SHALL BE REMOVED AND REINSTATED DURING BACKFILLING.6.#DN150 MM GRE PIPE LEAK RECTIFICATION WITH LAMINATION JOINT.7.#PIPELINE INLINE SERVICE TEST FOR WHICH DEWA WILL PROVIDE THE WATER AND CHARGE THE LINE WITH REQUIRED OPERATING PRESSURE.8.#IN CASE ANY LEAKAGE NOTICED DURING SERVICE TEST, CONTRACTOR SHALL REPAIR</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412600363  
**DATE** : 25.02.2026  
**REQ No** : 1032600242  
**REQ TITLE** : URGENT REQUIREMENT:  
**DELIVERY LOCATION**  
**CLOSING DATE** : 03.03.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>IMMEDIATELY AND IT IS COVERED UNDER THEIR WORK SCOPE.9.#UPON COMPLETION OF SERVICE TEST, BACK FILLING SHALL BE CARRIED OUT WITH THE REMOVED SAND. PROPER COMPACTION SHALL BE CARRIED OUT DURING BACK FILLING.10.#REINSTATEMENT OF INTERLOCK TILES. CONTRACTOR SHALL ENSURE THAT NO INTERLOCKS ARE DAMAGED DURING REMOVAL AND REINSTATEMENT PROCESS, IN CASE IF ANY INTERLOCKS ARE DAMAGED IT SHALL BE REPLACED BY CONTRACTOR.B.#VARIABLE WORK SCOPE: AS THE EXACT LOCATION OF THE PIPELINE LEAK IS NOT IDENTIFIED D. IN CASE IF IT IS NOT FOUND INSIDE EXCAVATED AREA AS MENTIONED ABOVE THE ADDITIONAL AREA WILL BE REQUIRED TO EXCAVATE BY PROTECTING THE NEARBY EXISTING NG PIPELINE FOUNDATIONS TO IDENTIFY PIPELINE LEAKAGE LOCATION. IN SUCH CASE CONTRACTOR IS REQUIRED TO PROVIDE UNIT</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412600363  
**DATE** : 25.02.2026  
**REQ No** : 1032600242  
**REQ TITLE** : URGENT REQUIREMENT:  
**DELIVERY LOCATION**  
**CLOSING DATE** : 03.03.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>RATE OF EXCAVATION PER CUBICMETER CONSIDERING ABOVE WORK SCOPE AND SAFETY REQUIREMENT. THE PAYMENTWILL BE BASED ON ACTUAL MEASUREME            NT OF THE QUANTITY AT SITE.CONTRACTOR TO PROVIDE THEIR QUOTE IN THE PRESCRIBED FORMAT BELOW.SERIAL NUMBER#WORK DESCRIPTION #UNIT OF MEASUREMENT#OFFERED PRICE1#PRICE SHALL BE QUOTED AS MENTIONED ABOVE IN A. FIX WORK SCOPEINCLUDING PRELIMINARY WORKS#LUMPSUM#2#PRICE SHALL BE QUOTED AS MENTIONED ABOVE IN B. VARIABLE WORK SCOPE#PER CUBIC METER#SITE REQUIREMENTS:1.#SINCE ALL ACTIVITIES ARE CONDUCTED WITHIN THE NATURAL GAS STATION,WHICH IS CLASSIFIED AS A HAZARDOUS AREA, ALL NECESSARY PRECAUTIONSRELATED TO SUCH ENVIRONMENTS MUST BE STRICTLY FOLLOWED.2.#ALL EXCAVATION SHALL BE DONE ONLY MANUALLY AND WITH THEPLASTIC/FIBER SHOVEL.3.#CONDUCT DAILY</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412600363  
**DATE** : 25.02.2026  
**REQ No** : 1032600242  
**REQ TITLE** : URGENT REQUIREMENT:  
**DELIVERY LOCATION**  
**CLOSING DATE** : 03.03.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SAFETY TOOLBOX  TALKS FOR ALL PERSONNEL PRIOR  TO COMMENCING WORK.4.#ENSURE ALL WORKERS  ARE EQUIPPED WITH THE NECESSARY  PERSONAL PROTECTIVE EQUIPMENT ( PPE)  SUCH AS SAFETY HELMETS, REFLECTIVE  VESTS,GLOVES, SAFETY BOOTS, AND  GOGGLES.5.#PROTECT PIPELINES NEAR THE  EXCAVATION WITH SCAFFOLDING AND  SECURE BARRICADES TO PREVENT  DAMAGE TO EXISTING UTILITIES.6.#MAINTAIN  A FULLY STOCKED FIRST AID BOX AND  ENSURE A FIRST AID ROOM IS ACCESSIBLE  ON-SITE AT ALL TIMES.7.#OBTAIN PRIOR  PERMISSION FROM THE DEWA IN CHARGE  BEFORE INITIATING ANY EXCAVATION OR  REPAIR ACTIVITIES.8.#ASSIGN ONLY  QUALIFIED, TRAINED, AND COMPETENT  PERSONNEL TO PERFORM EXCAVATION.  9.#IMPLEMENT ALL NECESSARY  PRECAUTIONARY AND PROTECTIVE  MEASURES PRIOR TO COMMENCING THE  WORK.10.#BARRICADE THE</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412600363  
**DATE** : 25.02.2026  
**REQ No** : 1032600242  
**REQ TITLE** : URGENT REQUIREMENT:  
**DELIVERY LOCATION**  
**CLOSING DATE** : 03.03.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>WORKING AREA USING WARNING TAPES, SAFETY CONES, ANDBARRIERS TO RESTRICT UNAUTHORIZED ACCESS.11.#VERIFY THAT ALL MATERIALS, TOOLS, AND EQUIPMENT USED ARE APPROVED,CERTIFIED, AND COMPLIANT WITH PR</p> <p>OJECT SPECIFICATIONS.12.#CLEARLY MARK AND DEFINE THE EXCAVATION AREA AROUND THE DAMAGEDPIPELINE. ENSURE THAT THE EXCAVATION WIDTH IS SUFFICIENT TO PROVIDE SAFEWORKING SPACE AND PROPER ACCESS FOR PIPE REPAIR.13.#PROVIDE ADEQUATE SHORING AND BRACING AS PER THE APPROVED DESIGN ANDENGINEER#S INSTRUCTIONS TO ENSURE EXCAVATION STABILITY.14.#UPON COMPLETION OF REPAIR ACTIVITIES, REMOVE ALL SHORING, B</p> <p>ACKFILLTHE EXCAVATION TO THE ORIGINAL GROUND LEVEL, COMPACT PROPERLY, AND CLEANTHE SITE THOROUGHLY.##GENERAL SAFETY PRECAUTIONS1.#AL</p> <p>L DEWA SAFETY &amp; ENVIRONMENT POLICY, RULES</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412600363  
**DATE** : 25.02.2026  
**REQ No** : 1032600242  
**REQ TITLE** : URGENT REQUIREMENT:  
**DELIVERY LOCATION**  
**CLOSING DATE** : 03.03.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>AND REGULATIONS SHALL BE FOLLOWED AT WORK SITE AND DEWA PREMISES DURING THE CONTRACT PERIOD . THE CONTRACTOR'S WORK WILL FALL WITHIN THE PURVIEW OF SAFETY SURVEYS CONDUCTED REGULARLY BY THE DEWA SAFETY SECTION. ALL THEIR SAFETY REQUIREMENTS SHALL BE PROMPTLY MET. 2.#THE CONTRACTOR SHALL CHECK THE CONDITION SUITABLE TO CARRY OUT THE WORK. CONDUCT SITE SURVEY AND SAFETY INSPECTION TO ASSESS THE WORKING ENVIRONMENT, PROPER ISOLATION &amp; OTHER HAZARDS. 3.#TOOL BOX TALK (TBT) SHALL BE GIVEN BY THE CONTRACTOR SUPERVISOR TO HIS STAFFS REGARDING THE NECESSARY STEPS TO BE TAKEN FOR SAFE EXECUTION OF WORKS INCLUDING RISK ASSESSMENT CARRIED OUT PRIOR TO THE SUBMISSION OF RISK ASSESSMENT SHEETS AND START OF WORK. 4.#WELDING, FLAME HEATING OR CUTTING, GRINDING, PNEUMA</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412600363  
**DATE** : 25.02.2026  
**REQ No** : 1032600242  
**REQ TITLE** : URGENT REQUIREMENT:  
**DELIVERY LOCATION**  
**CLOSING DATE** : 03.03.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>TIC CHIPPING,ETC. SHALL BE CARRIED OUT ONLY ON SPECIFIC CLEARANCE FROM DEWA THROUGH"HOT WORK PERMITS". THE HOT WORK PERMIT SHALL BE OBTAINED ON DAILYBASIS.5.#THE CONTRACTOR SHALL ENSURE THAT ADEQUATE FIRE PROTECTION EQUIPMENTAND MEN ARE AVAILABLE TO FIGHT ANY POSSIBLE HAZARDS. ALL DEWA RULES ANDREGULATIONS FOR HOT WORK PERMIT SHOULD BE STRICTLY FOLLOWED.6.#RISK ASSESSMENT (RA) SHALL BE UPDATED BASED ON THE PRESENTCONDITION, ENVIRONMENT AND WORKING STAFFS ON A CASE TO CASE BASIS. RASHOULD BE MORE SPECIFIC BASED ON THE WORK ON HAND AND PREVAILINGENVIRONMENT.7.#PLANT INSTALLATIONS, INSTRUMENTS, PIPING &amp; ELECTRICAL CABLES IN THEWORK OR ADJACENT AREA TO BE ADEQUATELY PROTECTED AGAINST DAMAGE WHILEEXECUTION OF THE CONTRACT</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412600363  
**DATE** : 25.02.2026  
**REQ No** : 1032600242  
**REQ TITLE** : URGENT REQUIREMENT:  
**DELIVERY LOCATION**  
**CLOSING DATE** : 03.03.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>WORK.8.#WHILE WORKING THE CONTRACTOR SHOULD BARRICADE THE AREA PR EVENTINGMOVEMENT OF PLANT OPERATORS AND MAINTENANCE PERSONNEL IN THE WORK AREA.9.#ONLY NON-SPARKING TOOLS SHOULD BE USED INCLUDING H ACK SAW, KNIFE,HAMMER AND CHISEL ETC. INSIDE NGPRS AND NG SYSTEM. THE DEWA SAFETY RULESAND REGULATIONS PERTAINING TO NG AND DFO SYST EM SHOULD BE STRICTLYFOLLOWED AND MONITORED BY THE SAFETY SUPERVISOR.10.#ALL EQUIPMENT LIKE RIGGING TOOLS, GRINDING MACHINES, DRILLI NGMACHINES, HAND TOOLS AND PRECISION TOOLS SHOULD HAVE VALID TESTCERTIFICATES FROM 3RD PARTY LICENSED CERTIFYING AGENCIES SHALL BEPR ODUCE BY THE CONTRACTOR.11.#THE CONTRACTOR SHALL CARRY OUT RISK ANALYSIS FOR ALL HIS WORKS.THIS RISK ANALYSIS SHALL BE FROM SAFETY AS WELL AS OCCUPATIONAL</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412600363  
**DATE** : 25.02.2026  
**REQ No** : 1032600242  
**REQ TITLE** : URGENT REQUIREMENT:  
**DELIVERY LOCATION**  
**CLOSING DATE** : 03.03.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>HEALTHCONSIDERATIONS.12.#ALL SPECIAL TOOLS, RIGGING TOOLS, INSPECTION TOOLS, TEMPORARYPLATFORMS, LADDERS, HOSES ETC., SHALL BE INSPECTED AND TESTED BYAPPROVED AUTHORITIES AND THE CONTRACTOR SHALL SUBMIT TO DEWA ON DEMANDWITH NECESSARY CERTIFICATION BEFORE THEIR USE AT SITE.13.#THE TEMPORARY OFFICE/STORES OF THE CONTRACTOR IN THE PREMISES OFDEWA SHALL BE CONSTRUCTED OF NON-FLAMMABLE MATERIAL. THE FACILITY SHALLHAVE ADEQUATE NUMBER OF HEALTHY FIRE EXTINGUISHERS FOR USE DURINGEMERGENCY SITUATIONS.14.#WELDING AND/OR OXY-ACY CYLINDER TROLLEYS, IF USED, AREA OF WELDINGAND FLAME CUTTING SHALL HAVE ADEQUATE NUMBER OF HEALTHY FIREEXTINGUISHERS, NON-ASBESTOS FLAME/HEAT BLANKETS. CYLINDERS TO BE CLOSEDWHILE NOT IN USE.15.#THE AREA OF WORK SHALL BE KEPT CLEAN AT ALL TIM</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412600363  
**DATE** : 25.02.2026  
**REQ No** : 1032600242  
**REQ TITLE** : URGENT REQUIREMENT:  
**DELIVERY LOCATION**  
**CLOSING DATE** : 03.03.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ES BEFORE, DURING AND AFTER T						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

**SPECIAL NOTES / INSTRUCTIONS:**

URGENT REQUIREMENT: UNDERGROUND FIRE WATER PIPELINE LEAK RECTIFICATION INSIDE NATURAL GAS STATION; PHASE 1; AL AWEER. for more information and details please contact: zamir.alware zamir.alware@dewa.gov.ae 04-81-40304 +971509152946

**STANDARD TERMS & CONDITIONS**

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.
- 6) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer.

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412600363  
**DATE** : 25.02.2026  
**REQ No** : 1032600242  
**REQ TITLE** : URGENT REQUIREMENT:  
**DELIVERY LOCATION**  
**CLOSING DATE** : 03.03.2026  
**CLOSING TIME** : 10:00:00

If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements  
The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

**SUPPLIER'S REMARKS :**

**SUPPLIER'S SIGNATURE AND STAMP**