

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600381
DATE : 03.03.2026
REQ No : 1172501437
REQ TITLE : SITC AIR-COOLED CHILLER
DELIVERY LOCATION
CLOSING DATE : 16.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1	7000000011		<p>SUPPLY, REPLACEMENT, TESTING & COMMISSIONING OF AIR-COOLED CHILLER AT ALHUDAIBAH CHC. PART 1 # GENERAL:1.1GENERAL DESCRIPTION:THIS SPECIFICATION COVERS THE DESIGN, SUPPLY, REPLACEMENT, TESTING, AND COMMISSIONING OF ONE AIR-COOLED CHILLER (CHILLER NO-2), INCLUDING THE REMOVAL OF THE EXISTING UNIT, COMPLETE MECHANICAL AND ELECTRICAL INTEGRATION WITH THE EXISTING CHILLED WATER SYSTEM, CIVIL FOUNDATION MODIFICATIONS, AND ALL ASSOCIATED ACCESSORIES AND CONTROLS. PARTICIPATING VENDORS SHALL CONDUCT A DETAILED SITE SURVEY TO VERIFY THE EXISTING CHILLED WATER FLOW, PIPING LAYOUT, BUILDING DIMENSIONS, ROOF/INSTALLATION AREA, AND ELECTRICAL CONNECTIVITY. VENDORS SHALL MEASURE AND RECORD THE EXISTING CHILLED WATER SYSTEM PARAMETERS (INCLUDING FLOW RATE, TEMPERATURE, PRESSURE, AND</p>	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600381
DATE : 03.03.2026
REQ No : 1172501437
REQ TITLE : SITC AIR-COOLED CHILLER
DELIVERY LOCATION
CLOSING DATE : 16.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>DIFFERENTIALPRESSURE, WHERE APPLICABLE) AS PART OF THEIR ASSESSMENT AND PROPOSAL.THE WORKS SHALL BE CARRIED OUT IN ACCORDANCE WITH ASHRAE, AHRI, ARI,SMAC NA, BS/EN, DUBAI CIVIL DEFENCE, AND DEWA REGULATIONS. ALL MATERIALSAND EQUIPMENT SHALL BE SUITABLE FOR OPERATION IN DUBAI#S HIGH AMB IENTTEMPERATURE (UP TO 52°C DRY BULB / 32°C WET BULB).THE AIR-COOLED CHILLER WORK IS INDICATED BY DRAWINGS AND SCHEDULES, ANDBY REQU IREMENTS OF THIS SECTION. EACH UNIT IS DEFINED TO INCLUDE (BUTNOT BY WAY OF LIMITATION), SEMI HERMETIC SCREW COMPRESSORS, EVAPORATOR ,AIR-COOLED CONDENSER, CONTROLS AND PANEL INCLUDING GAGES AND INDICATINGLIGHTS, AUXILIARY COMPONENTS, ACCESSORIES AND INTERCONNECTIN G PIPING.REQUIRED WORK ALSO INCLUDES ADDITIONAL REQUIREMENTS AS COMPRESSOR</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600381
DATE : 03.03.2026
REQ No : 1172501437
REQ TITLE : SITC AIR-COOLED CHILLER
DELIVERY LOCATION
CLOSING DATE : 16.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ANDFAN, MOTOR STARTERS, VIBRATION ISOLATORS AND SEISMIC (EARTHQUAKE)RESTRAINERS, EVAPORATOR INSULATION, ANCHOR BOLTS AND ALL REQUIREDACCESSORIES BY THE MANUFACTURER. CHILLER SHALL BE OF HIGH OUTDOORTEMPERATURE VERSION, LOW NOISE VERSION WITH ADEQUATE LOW NOISE HIGHSTATIC CONDENSER FANS TO INSTALL CHILLER INDOOR AND TO DUCT THECONDENSER AIR TO OUTSIDE AND 2 OR 3 INDEPENDENT REFRIGERATION CIRCUITSCOMPLETE WITH AS DETAILED ON DRAWINGS.DURING THE REPLACEMENT OF THE CHILLERS, THE CHILLED WATER SYSTEMPRESSURIZATION UNIT SHALL ALSO BE REPLACED WITH A NEW ONE, MATCHING THEEXISTING FLOW RATE AND CAPACITY, TO ENSURE PROPER MAINTENANCE OF THECHILLED WATER FLOW IN THE NETWORK.1.2QUALITY ASSURANCE:1.MANUFACTURER: A FIRM REGULARLY ENGAGED IN MANUFACTURE OF</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600381
DATE : 03.03.2026
REQ No : 1172501437
REQ TITLE : SITC AIR-COOLED CHILLER
DELIVERY LOCATION
CLOSING DATE : 16.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>AIR-COOLEDCHILLERS, OF TYPES, SIZES AND CAPACITIES REQUIRED, WHOSE PRODUCTS HAVEBEEN SUCCESSFULLY USED IN SIMILAR SERVICE FOR NOT LESS THAN FIVE YEARS.CHILLER MANUFACTURER MUST BE ISO9001 REGISTERED.2.CERTIFICATION: CERTIFY PERFORMANCE OF CHILLER AT FULL-LOAD SCHEDULEDVALUES FOR CAPACITY, POWER LOAD, CHILLED WATER LEAVING TEMPERATURE ANDFLOW AND FOULING FACTORS. INCLUDE A REPORT OF EXPECTED PERFORMANCE ATPART-LOAD CONDITIONS, FOR 80%, 60%, 40% AND 20% OF SCHEDULED FULL-LOADCAPACITY. SHOW PERFORMANCE DATA IN TERMS OF LOAD VERSUSDEWA-CONFIDENTIALACTUAL CAPACITY. CHILLER SHALL BE FULLY MODULATING TYPE. FOR CERTIFIEDAND EXPECTED PERFORMANCE CAPACITIES, INCLUDING TOTAL HEAT REJECTIONVALUES (INCLUDING EFFECTS OF TRANSMISSION FOR PURGE AND REFRIGERANTTRANSFER SYSTEMS.</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600381
DATE : 03.03.2026
REQ No : 1172501437
REQ TITLE : SITC AIR-COOLED CHILLER
DELIVERY LOCATION
CLOSING DATE : 16.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>MS) TOTAL POWER-INPUT REQUIREMENTS, EVAPORATOR TUBEVELOCITIES.3.TYPICAL PERFORMANCE DATA: PREPARE DATA FOR (ANSI/ARI 590) SCHEDULES FULL-LOAD CAPACITY USING "STANDARD RATING CONDITIONS", PART-LOAD AT 80%,60% 40%, AND 20% OF SCHEDULED FULL-LOAD CAPACITY USING "APPLICATION RATING CONDITIONS".4.CERTIFY THAT SOUND PRESSURE LEVEL WILL NOT EXCEED SCHEDULED VALUES WHEN TESTED IN ACCORDANCE WITH ARI 575. INCLUDE REPORT OF EXPECTED SOUND PRESSURE LEVEL WITH CHILLER OPERATING AT SCHEDULED CAPACITY AND INCLUDE ALSO REPORT OF EXPECTED SOUND PRESSURE LEVEL FOR EACH SCHEDULE CAPACITY INCLUDING PART-LOAD CAPACITIES.5.CHILLERS SHALL CARRY ISO 9001 AND ISO 14001 CERTIFICATIONS.6.RATINGS: RATE CHILLER IN ACCORDANCE WITH ARI 590 OR EN14511 AND SOUND LEVELS WITH ISO 9614 AND EURO VENT</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600381
DATE : 03.03.2026
REQ No : 1172501437
REQ TITLE : SITC AIR-COOLED CHILLER
DELIVERY LOCATION
CLOSING DATE : 16.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>STANDARDS.7.SAFETY: COMPLY WITH ANSI/ASHRAE 15, SAFETY CODE FOR MECHANICAL REFRIGERATION.8.UL LABELS: PROVIDE CHILLER ELECTRICAL COMPONENTS WHICH HAVE BEEN LISTED AND LABELED BY UNDERWRITERS LABORATORIES.9.NEMA COMPLIANCE: COMPLY WITH APPLICABLE PORTIONS OF NATIONAL ELECTRICAL MANUFACTURERS ASSOCIATION STANDARDS PERTAINING TO CHILLER MOTORS AND MOTOR ENERGY MANAGEMENT.10.STANDARDS FOR DESIGN, FABRICATION AND INSTALLATION: EXCEPT AS OTHERWISE INDICATED, COMPLY WITH FOLLOWING: ASME BOILER AND PRESSURE VESSEL CODE. PROVIDE ASME STAMP ON CHILLER SHOWING COMPLIANCE WITH ASME CODE. NATIONAL ELECTRICAL CODE. ANSI B31.1 POWER PIPING CODE. ASHRAE STANDARD 90-75, AS APPLICABLE TO AIR-COOLED WATER CHILLERS. SHOW COMPLIANCE WITH, BUT NOT BY WAY OF LIMITATION, MINIMUM</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600381
DATE : 03.03.2026
REQ No : 1172501437
REQ TITLE : SITC AIR-COOLED CHILLER
DELIVERY LOCATION
CLOSING DATE : 16.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ENERGY EFFICIENCY RATIO (EER). OR ALTERNATIVELY, CHILLER SHALL BE CE MARKED. 11. CHILLERS SHALL UNDERGO A COMPLETE RUN TEST IN THE FACTORY BEFORE SHIPMENT. 1.3 SUBMITTALS: SUBMIT MANUFACTURER'S DATA ON AIR-COOLED CHILLERS, INCLUDING CERTIFIED DRAWINGS SHOWING OVERALL DIMENSIONS OF COMPLETE ASSEMBLY, OPERATING WEIGHTS, FOUNDATION REQUIREMENTS, SIZES, AND LOCATIONS OF CONNECTION, ACCESSORIES, AUXILIARY SUPPORT REQUIREMENTS, AND PARTS LISTS. INCLUDE THE FOLLOWING INFORMATION: 1. PERFORMANCE CERTIFICATIONS AND REPORTS. 2. WIRING DIAGRAMS SHOWING ELECTRIC SERVICE FOR CHILLER ELECTRICAL COMPONENTS, SAFETY DEVICES AND INDICATOR LIGHTS. 3. WRITTEN INSTRUCTIONS FOR INSTALLATION AND ASSEMBLY. 4. WRITTEN LISTING OF LIMITING CONDITIONS FOR CHILLER OPERATION. DEWA-CONFIDENTIAL 5.</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600381
DATE : 03.03.2026
REQ No : 1172501437
REQ TITLE : SITC AIR-COOLED CHILLER
DELIVERY LOCATION
CLOSING DATE : 16.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>WRITTEN OPERATING INSTRUCTIONS INCLUDING START-UP, ROUTINE AND NORMAL OPERATIONS, REGULATIONS AND CONTROLS AND SHUTDOWN FOR EMERGENCIES.6. WRITTEN SERVICE INSTRUCTIONS INCLUDING MANUFACTURER'S RECOMMENDATION ON STOCKING OF SPARE PARTS, INCLUDING GASKETS AND O-RINGS.7. REPORT SIGNED BY CHILLER MANUFACTURER'S REPRESENTATIVE, INDICATING THAT WORK HAS BEEN PROPERLY INSTALLED IN ACCORDANCE WITH MANUFACTURER'S WRITTEN INSTRUCTIONS.8. TOOL KIT, INCLUDING MANUFACTURER'S SPECIAL TOOLS AND NON-STANDARD WRENCHES REQUIRED FOR SERVICING CHILLER.9. PROVIDE WRITTEN WARRANTY ON AIR-COOLED CHILLER WORK, AGREEING TO REPLACE/REPAIR INADEQUATE AND DEFECTIVE MATERIALS AND WORKMANSHIP, INCLUDING LEAKAGE, BREAKAGE, IMPROPER ASSEMBLY AND FAILURE TO PERFORMS REQUIRED. INCLUDE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600381
DATE : 03.03.2026
REQ No : 1172501437
REQ TITLE : SITC AIR-COOLED CHILLER
DELIVERY LOCATION
CLOSING DATE : 16.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>INGSEPARATE PRODUCT WARRANTIES AS INDICATED (IF ANY) FOR SPECIFIC PARTS OR PRODUCTS IN THE WORK. PROVIDE WARRANTY SIGNED BY THE CONTRACTOR. 10. INCLUDE MANUFACTURER'S STANDARD PRODUCT WARRANTY, COVERING CHILLER OPERATION UNDER NORMAL CONDITIONS AND USE, WHERE INSTALLED, OPERATED AND MAINTAINED IN ACCORDANCE WITH MANUFACTURER'S INSTRUCTIONS. PROVIDE PRODUCT WARRANTY PERIOD TERMINATING 12 MONTHS AFTER START-UP OF THE CHILLER INSTALLATION. 11. SPECIAL WARRANTY PERIOD IS 2 YEARS AFTER DATE OF SUBSTANTIAL COMPLETION. PART 2 # PRODUCTS: SCR</p> <p>EW TYPE CHILLERS 2.1 GENERAL 1. THE CONTRACTOR SHALL SUPPLY AND INSTALL FACTORY-ASSEMBLED, AIR-COOLED, PACKAGED COOLING-ONLY CHILLERS, WITH CAPACITIES MATCHING THOSE OF THE EXISTING CHILLERS. 2. EACH MACHINE SHALL CONSIST OF AT LEAST TWO ACCESSIBLE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600381
DATE : 03.03.2026
REQ No : 1172501437
REQ TITLE : SITC AIR-COOLED CHILLER
DELIVERY LOCATION
CLOSING DATE : 16.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>HERMETIC FULLYMODULATING SCREW COMPRESSORS AIR-COOLED CONDENSER, EVAPORATOR,INTERCONNECTING REFRIGERANT PIPING, CONTROLS, SAFETY DEVICES,ACCESSORIES, AND CONTROL POWER TRANSFORMER AS APPLICABLE TO LIMITCONTROL VOLTAGE TO 240 VOLTS MAXIMUM. NO PHASE TO NEUTRAL VOLTAGE SHALLBE REQUIRED. EACH COMPRESSOR SHALL HAVE ITS INDEPENDENT CIRCUIT,EVAPORATOR, CONDENSER, MICROPROCESSOR-BASED CONTROLS AND A UNIT MOUNTEDMOTOR STARTER.3.THE MACHINE SHALL BE COMPLETELY CHARGED AT THE FACTORY WITH REFRIGERANT R134A OR R410A. ALL FACTORY WIRING AND PIPING SHALL BE CONTAINED WITHIN THE MACHINE ENCLOSURE. ALL ELECTRICAL COMPONENTS SHALL BE PROTECTED FROM THE WEATHER.4.THE REFRIGERANT CIRCUIT COMPONENTS SHALL INCLUDE HOT GAS MUFFLER, HIGHSIDE PRESSURE RELIEF VALVE, LIQUID LINE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600381
DATE : 03.03.2026
REQ No : 1172501437
REQ TITLE : SITC AIR-COOLED CHILLER
DELIVERY LOCATION
CLOSING DATE : 16.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SHUT OFF VALVE FILTER DRIER, LIQUID LINE SIGHT GLASS, LIQUID LINE SOLENOID VALVE AND THERMALEXPANSION VALVE. DEWA-CONFIDENTIAL 5. EACH MACHINE SHALL BE ENCLOSED IN A SOUND ATTENUATING, GALVANIZED STEEL CASING, ZINC PHOSPHATIZED, WITH CORROSION RESISTANT FINISH, AND SHALL BE MOUNTED ON SPRING TYPE VIBRATION ISOLATORS.						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

SITC AIR-COOLED CHILLER AT AL HUDAIBAH CHC.

Contact : Mohideen / 553810513

Payment Terms ; 30% upon delivery of materials, 65% upon project handover / Retention : 5%

STANDARD TERMS & CONDITIONS

1) Prices should be 'DDP' delivery duty paid at DEWA stores.

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600381
DATE : 03.03.2026
REQ No : 1172501437
REQ TITLE : SITC AIR-COOLED CHILLER
DELIVERY LOCATION
CLOSING DATE : 16.03.2026
CLOSING TIME : 10:00:00

- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard Payment will be made within 30 days from the date the Supplier/Contractor submits a complete and accurate invoice, together with all required supporting documents, subject to the material and/or services having been duly accepted.
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/or services in the Quotation, shall be confirming and in accordance with DEWA Energy Management Policy & EnMS Manual.
- 6) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer. If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP