

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600444
DATE : 12.03.2026
REQ No : 1032600242
REQ TITLE : URGENT REQUIREMENT:
DELIVERY LOCATION
CLOSING DATE : 18.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	<p>REMOVAL OF INTERLOCK, EXCAVATION, EXPOSING GRE FIRE WATER PIPELINE, 150MM DIAMETER GRE PIPE LEAK RECTIFICATION, SERVICE PRESSURE TES</p> <p>T POST LEAKRECTIFICATION BY NORMALIZING THE SYSTEM, BACK FILLING, COMPACTION, INTERLOCK TILES REFIXING AND REINSTATEMENT OF AREA INSI</p> <p>DE NATURAL GASSTATION AT H-STATION, PHASE-1, AL-AWEER.SCOPE OF WORK:CONTRACTOR TO CONSIDER FOLLOWING WORK</p> <p>SCOPE,PRELIMINARY PREPARAT</p> <p>ORY WORKS:1.#EXCAVATE A TRIAL PIT OF 80 CM WIDTH TO LOCATE THE LEAK AREA ANDFULLY EXPOSE THE EXISTING GRE PIPELINE, FOLLOWING THE EN</p> <p>GINEER#SINSTRUCTIONS IN THE CENTRALLY MARKED RED ZONE.A.#FIX WORK</p> <p>SCOPE:1.#REMOVAL OF INTERLOCK TILES FOR 3-METER-WIDE X 4 METER LON</p> <p>G = 12SQUARE METER.2.#EXCAVATION FOR 2.2-METER-WIDE X 2-METER-DEEP X 4 METER LONG = 17.6CUBIC METER OF VOLUME AS SHOWN</p>	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600444
DATE : 12.03.2026
REQ No : 1032600242
REQ TITLE : URGENT REQUIREMENT:
DELIVERY LOCATION
CLOSING DATE : 18.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>IN THE BELOW SKETCH.3.#THE EXCAVATION SHALL BE CONDUCTED IN STEPS AS SHOWN ABOVE.4.#THERE ARE THREE NG PIPELINE FOUNDATIONS LOCATED NEAR TO THEEX CAVATION AREA WHICH ARE HAVING DEPTH OF BOC AT -1.250 METER, HENCEDURING EXCAVATION BELOW THE DEPTH OF 1.25 METER THE SOIL AROUND NG FOUNDATION SHALL BE PROTECTED BY MEANS OF SHORING / STEEL PLATE JACKINGSYSTEM. THE SUPPORTING SYSTEM SHALL BE ROBUST TO PREVENT ANY CHANCE OFSOIL COLLAPSE. THE EXCAVATION SHALL BE DONE IN SAFE MANNER ANDPROTECTING NG FOUNDATIONS.5.#AS THE HEIGHT OF THE EXCAVATION IS AROUND 2 TO 2.2 METERS CONTRACTORSHALL PROVIDE PROPER SLOPE/STEP CUTTING DURING EXCAVATION AND PROTECTIONAGAINST COLLAPSING LOOSE SAND SHALL BE PROVIDED. IN EXISTING PLANT,APPROXIMATE HEIGHT OF 300 MM</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600444
DATE : 12.03.2026
REQ No : 1032600242
REQ TITLE : URGENT REQUIREMENT:
DELIVERY LOCATION
CLOSING DATE : 18.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>CONCRETE MIXTURE IS PLACED BELOW INTERLOCKTILES THIS SHALL BE REMOVED AND REINSTATED DURING BACKFILLING.6.#DN150 MM GRE PIPE LEAK RECTIFICATION WITH LAMINATION JOINT.7.#PIPELINE INLINE SERVICE TEST FOR WHICH DEWA WILL PROVIDE THE WATERAND CHARGE THE LINE WITH REQUIRED OPERATING PRESSURE.8.#IN CASE ANY LEAKAGE NOTICED DURING SERVICE TEST, CONTRACTOR SHALLREPAIR IMMEDIATELY AND IT IS COVERED UNDER THEIR WORK SCOPE.9.#UPON COMPLETION OF SERVICE TEST, BACK FILLING SHALL BE CARRIED OUTWITH THE REMOVED SAND. PROPER COMPACTION SHALL BE CARRIED OUT DURINGBACKFILLING.10.#REINSTATEMENT OF INTERLOCK TILES. CONTRACTOR SHALL ENSURE THAT NOINTERLOCKS ARE DAMAGED DURING REMOVAL AND REINSTATEMENT PROCESS, IN CASEIF ANY INTERLOCKS ARE DAMAGED IT SHALL BE REPLACED BY</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600444
DATE : 12.03.2026
REQ No : 1032600242
REQ TITLE : URGENT REQUIREMENT:
DELIVERY LOCATION
CLOSING DATE : 18.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>CONTRACTOR.B.#VARIABLE WORK SCOPE:AS THE EXACT LOCATION OF THE PIPELINE LEAK IS NOT IDENTIFIE</p> <p>D. IN CASE IFIT IS NOT FOUND INSIDE EXCAVATED AREA AS MENTIONED ABOVE THE ADDITIONALAREA WILL BE REQUIRED TO EXCAVATE BY PROTECTING THE NEARBY EXISTING NGPIPELINE FOUNDATIONS TO IDENTIFY PIPELINE LEAKAGE LOCATION. IN SUCH CASECONTRACTOR IS REQUIRED TO PROVIDE UNIT</p> <p>RATE OF EXCAVATION PER CUBICMETER CONSIDERING ABOVE WORK SCOPE AND SAFETY REQUIREMENT. THE PAYMENTWILL BE BASED ON ACTUAL MEASUREME</p> <p>NT OF THE QUANTITY AT SITE.CONTRACTOR TO PROVIDE THEIR QUOTE IN THE PRESCRIBED FORMAT BELOW.SERIAL NUMBER#WORK DESCRIPTION #UNIT OF MEASUREMENT#OFFERED PRICE1#PRICE SHALL BE QUOTED AS MENTIONED ABOVE IN A. FIX WORK SCOPEINCLUDING PRELIMINARY WORKS#LUMPSUM#2#PRICE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600444
DATE : 12.03.2026
REQ No : 1032600242
REQ TITLE : URGENT REQUIREMENT:
DELIVERY LOCATION
CLOSING DATE : 18.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SHALL BE QUOTED AS MENTIONED ABOVE IN B. VARIABLE WORK SCOPE#PER CUBIC METER#SITE REQUIREMENTS:1.#SINCE ALL ACTIVITIES ARE CONDUCTED WITHIN THE NATURAL GAS STATION,WHICH IS CLASSIFIED AS A HAZARDOUS AREA, ALL NECESSARY PRECAUTIONSRELATED TO SUCH ENVIRONMENTS MUST BE STRICTLY FOLLOWED.2.#ALL EXCAVATION SHALL BE DONE ONLY MANUALLY AND WITH THEPLASTIC/FIBER SHOVEL.3.#CONDUCT DAILY SAFETY TOOLBOX TALKS FOR ALL PERSONNEL PRIOR TOCOMMENCING WORK.4.#ENSURE ALL WORKERS ARE EQUIPPED WITH THE NECESSARY PERSONALPROTECTIVE EQUIPMENT (PPE) SUCH AS SAFETY HELMETS, REFLECTIVE VESTS,GLOVES, SAFETY BOOTS, AND GOGGLES.5.#PROTECT PIPELINES NEAR THE EXCAVATION WITH SCAFFOLDING AND SECUREBARRICADES TO PREVENT DAMAGE TO EXISTING UTILITIES.6.#MAINTAIN A FULLY STOCKED FIRST AID BOX AND ENSURE A</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600444
DATE : 12.03.2026
REQ No : 1032600242
REQ TITLE : URGENT REQUIREMENT:
DELIVERY LOCATION
CLOSING DATE : 18.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>FIRST AID ROOMS ACCESSIBLE ON-SITE AT ALL TIMES.7.#OBTAIN PRIOR PERMISSION FROM THE DEWA IN CHARGE BEFORE INITIATING ANY EXCAVATION OR REPAIR ACTIVITIES.8.#ASSIGN ONLY QUALIFIED, TRAINED, AND COMPETENT PERSONNEL TO PERFORM EXCAVATION.9.#IMPLEMENT ALL NECESSARY PRECAUTIONARY AND PROTECTIVE MEASURES PRIOR TO COMMENCING THE WORK.10.#BARRICADE THE WORKING AREA USING WARNING TAPES, SAFETY CONES, AND BARRIERS TO RESTRICT UNAUTHORIZED ACCESS.11.#VERIFY THAT ALL MATERIALS, TOOLS, AND EQUIPMENT USED ARE APPROVED, CERTIFIED, AND COMPLIANT WITH PROJECT SPECIFICATIONS.12.#CLEARLY MARK AND DEFINE THE EXCAVATION AREA AROUND THE DAMAGED PIPELINE. ENSURE THAT THE EXCAVATION WIDTH IS SUFFICIENT TO PROVIDE SAFE WORKING SPACE AND PROPER ACCESS FOR PIPE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600444
DATE : 12.03.2026
REQ No : 1032600242
REQ TITLE : URGENT REQUIREMENT:
DELIVERY LOCATION
CLOSING DATE : 18.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>REPAIR.13.#PROVIDE ADEQUATE SHORING AND BRACING AS PER THE APPROVED DESIGN ANDENGINEER#S INSTRUCTIONS TO ENSURE EXCAVATION STABILITY.14.#UPON COMPLETION OF REPAIR ACTIVITIES, REMOVE ALL SHORING, B</p> <p>ACKFILLTHE EXCAVATION TO THE ORIGINAL GROUND LEVEL, COMPACT PROPERLY, AND CLEANTHE SITE THOROUGHLY.##GENERAL SAFETY PRECAUTIONS1.#ALL DEWA SAFETY & ENVIRONMENT POLICY, RULES AND REGULATIONS SHALL BEFOLLOWED AT WORK SITE AND DEWA PREMISES DURING THE CONTRACT PERIOD</p> <p>. THECONTRACTOR'S WORK WILL FALL WITHIN THE PURVIEW OF SAFETY SURVEYSCONDUCTED REGULARLY BY THE DEWA SAFETY SECTION. ALL THEIR SAFETY REQUIREMENTS SHALL BE PROMPTLY MET.2.#THE CONTRACTOR SHALL CHECK THE CONDITION SUITABLE TO CARRY OUT THEWORK. CONDUCT SITE SURVEY A</p> <p>ND SAFETY INSPECTION TO ASSESS THE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600444
DATE : 12.03.2026
REQ No : 1032600242
REQ TITLE : URGENT REQUIREMENT:
DELIVERY LOCATION
CLOSING DATE : 18.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>WORKINGENVIRONMENT, PROPER ISOLATION & OTHER HAZARDS.3.#TOOL BOX TALK (TBT) SHALL BE GIVEN BY THE CONTRACTOR SUPERVISOR TOHIS STAFFS REGARDING THE NECESSARY STEPS TO BE TAKEN FOR SAFE EXECUTIONOF WORKS INCLUDING RISK ASSESSMENT CARRIED OUT PRIOR TO THE SUBMISSIONOF RISK ASSESSMENT SHEETS AND START OF WORK.4.#WELDING, FLAME HEATING OR CUTTING, GRINDING, PNEUMATIC CHIPPING,ETC. SHALL BE CARRIED OUT ONLY ON SPECIFIC CLEARANCE FROM DEWA THROUGH"HOT WORK PERMITS". THE HOT WORK PERMIT SHALL BE OBTAINED ON DAILYBASIS.5.#THE CONTRACTOR SHALL ENSURE THAT ADEQUATE FIRE PROTECTION EQUIPMENTAND MEN ARE AVAILABLE TO FIGHT ANY POSSIBLE HAZARDS. ALL DEWA RULES ANDREGULATIONS FOR HOT WORK PERMIT SHOULD BE STRICTLY FOLLOWED.6.#RISK ASSESSMENT (RA) SHALL BE UPDATED</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600444
DATE : 12.03.2026
REQ No : 1032600242
REQ TITLE : URGENT REQUIREMENT:
DELIVERY LOCATION
CLOSING DATE : 18.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>BASED ON THE PRESENTCONDITION, ENVIRONMENT AND WORKING STAFFS ON A CASE TO CASE BASIS. RASHOULD BE MORE SPECIFIC BASED ON THE WORK ON HAND AND PREVAILINGENVIRONMENT.7.#PLANT INSTALLATIONS, INSTRUMENTS, PIPING & ELECTRICAL CABLES IN THEWORK OR ADJACENT AREA TO BE ADEQUATELY PROTECTED AGAINST DAMAGE WHILEEXECUTION OF THE CONTRACT WORK.8.#WHILE WORKING THE CONTRACTOR SHOULD BARRICADE THE AREA PR EVENTINGMOVEMENT OF PLANT OPERATORS AND MAINTENANCE PERSONNEL IN THE WORK AREA.9.#ONLY NON-SPARKING TOOLS SHOULD BE USED INCLUDING H ACK SAW, KNIFE,HAMMER AND CHISEL ETC. INSIDE NGPRS AND NG SYSTEM. THE DEWA SAFETY RULESAND REGULATIONS PERTAINING TO NG AND DFO SYST EM SHOULD BE STRICTLYFOLLOWED AND MONITORED BY THE SAFETY SUPERVISOR.10.#ALL</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600444
DATE : 12.03.2026
REQ No : 1032600242
REQ TITLE : URGENT REQUIREMENT:
DELIVERY LOCATION
CLOSING DATE : 18.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>EQUIPMENT LIKE RIGGING TOOLS, GRINDING MACHINES, DRILLI NGMACHINES, HAND TOOLS AND PRECISION TOOLS SHOULD HAVE VALID TESTCERTIFICATES FROM 3RD PARTY LICENSED CERTIFYING AGENCIES SHALL BEPR ODUCE BY THE CONTRACTOR.11.#THE CONTRACTOR SHALL CARRY OUT RISK ANALYSIS FOR ALL HIS WORKS.THIS RISK ANALYSIS SHALL BE FROM SAFETY AS WELL AS OCCUPATIONAL HEALTHCONSIDERATIONS.12.#ALL SPECIAL TOOLS, RIGGING TOOLS, INSPECTION TOOLS, TEMPORARYPLATFORMS, LADDERS, HOSES ETC., SHALL BE INSPECTED AND TESTED BYAPPROVED AUTHORITIES AND THE CONTRACTOR SHALL SUBMIT TO DEWA ON DEMANDWITH NECESSARY CERTI FICATION BEFORE THEIR USE AT SITE.13.#THE TEMPORARY OFFICE/STORES OF THE CONTRACTOR IN THE PREMISES OFDEWA SHALL BE CONSTRUCTED OF N ON-FLAMMABLE MATERIAL. THE FACILITY</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600444
DATE : 12.03.2026
REQ No : 1032600242
REQ TITLE : URGENT REQUIREMENT:
DELIVERY LOCATION
CLOSING DATE : 18.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SHALL HAVE ADEQUATE NUMBER OF HEALTHY FIRE EXTINGUISHERS FOR USE DURING EMERGENCY SITUATIONS.14.#WELDING AND/OR OXY-ACYLINDER TROLLEYS, IF USED, AREA OF WELDING AND FLAME CUTTING SHALL HAVE ADEQUATE NUMBER OF HEALTHY FIRE EXTINGUISHERS, NON-ASBESTOS FLAME/HEAT BLANKETS. CYLINDERS TO BE CLOSED WHILE NOT IN USE.15.#THE AREA OF WORK SHALL BE KEPT CLEAN AT ALL TIMES BEFORE, DURING AND AFTER T						
2		ITEM-00001	REMOVAL OF INTERLOCK, EXCAVATION, EXPOSING GRE FIRE WATER PIPELINE, 150MM DIAMETER GRE PIPE LEAK RECTIFICATION, SERVICE PRESSURE TEST POST LEAK RECTIFICATION BY NORMALIZING THE SYSTEM, BACK FILLING, COMPACTION, INTERLOCK TILES REFIXING AND REINSTATEMENT OF AREA INSIDE NATURAL GAS STATION AT H-STATION, PHASE-1, AL-AWEER. SCOPE OF WORK: CONTRACTOR TO CONSIDER FOLLOWING WORK	4	CBM				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600444
DATE : 12.03.2026
REQ No : 1032600242
REQ TITLE : URGENT REQUIREMENT:
DELIVERY LOCATION
CLOSING DATE : 18.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SCOPE,PRELIMINARY PREPARATORY WORKS:1.#EXCAVATE A TRIAL PIT OF 80 CM WIDTH TO LOCATE THE LEAK AREA ANDFULLY EXPOSE THE EXISTING GRE PIPELINE, FOLLOWING THE ENGINEER#SINSTRUCTIONS IN THE CENTRALLY MARKED RED ZONE.A.#FIX WORK</p> <p>SCOPE:1.#REMOVAL OF INTERLOCK TILES FOR 3-METER-WIDE X 4 METER LONG = 12 SQUARE METER.2.#EXCAVATION FOR 2.2-METER-WIDE X 2-METER-DEEP X 4 METER LONG = 17.6CUBIC METER OF VOLUME AS SHOWN IN THE BELOW SKETCH.3.#THE EXCAVATION SHALL BE CONDUCTED IN STEPS AS SHOWN ABOVE.4.#THERE ARE THREE NG PIPELINE FOUNDATIONS LOCATED NEAR TO THE EXCAVATION AREA WHICH ARE HAVING DEPTH OF BOC AT -1.250 METER, HENCE DURING EXCAVATION BELOW THE DEPTH OF 1.25 METER THE SOIL AROUND NG FOUNDATION SHALL BE PROTECTED BY MEANS OF SHORING / STEEL PLATE JACKING SYSTEM. THE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600444
DATE : 12.03.2026
REQ No : 1032600242
REQ TITLE : URGENT REQUIREMENT:
DELIVERY LOCATION
CLOSING DATE : 18.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SUPPORTING SYSTEM SHALL BE ROBUST TO PREVENT ANY CHANCE OF SOIL COLLAPSE. THE EXCAVATION SHALL BE DONE IN SAFE MANNER AND PROTECTING NG FOUNDATIONS.5.#AS THE HEIGHT OF THE EXCAVATION IS AROUND 2 TO 2.2 METERS CONTRACTOR SHALL PROVIDE PROPER SLOPE/STEP CUTTING DURING EXCAVATION AND PROTECTION AGAINST COLLAPSING LOOSE SAND SHALL BE PROVIDED. IN EXISTING PLANT, APPROXIMATE HEIGHT OF 300 MM CONCRETE MIXTURE IS PLACED BELOW INTERLOCK TILES THIS SHALL BE REMOVED AND REINSTATED DURING BACKFILLING.6.#DN150 MM GRE PIPE LEAK RECTIFICATION WITH LAMINATION JOINT.7.#PIPELINE INLINE SERVICE TEST FOR WHICH DEWA WILL PROVIDE THE WATER AND CHARGE THE LINE WITH REQUIRED OPERATING PRESSURE.8.#IN CASE ANY LEAKAGE NOTICED DURING SERVICE TEST, CONTRACTOR SHALL REPAIR</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600444
DATE : 12.03.2026
REQ No : 1032600242
REQ TITLE : URGENT REQUIREMENT:
DELIVERY LOCATION
CLOSING DATE : 18.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>IMMEDIATELY AND IT IS COVERED UNDER THEIR WORK SCOPE.9.#UPON COMPLETION OF SERVICE TEST, BACK FILLING SHALL BE CARRIED OUT WITH THE REMOVED SAND. PROPER COMPACTION SHALL BE CARRIED OUT DURING BACK FILLING.10.#REINSTATEMENT OF INTERLOCK TILES. CONTRACTOR SHALL ENSURE THAT NO INTERLOCKS ARE DAMAGED DURING REMOVAL AND REINSTATEMENT PROCESS, IN CASE IF ANY INTERLOCKS ARE DAMAGED IT SHALL BE REPLACED BY CONTRACTOR.B.#VARIABLE WORK SCOPE: AS THE EXACT LOCATION OF THE PIPELINE LEAK IS NOT IDENTIFIED D. IN CASE IF IT IS NOT FOUND INSIDE EXCAVATED AREA AS MENTIONED ABOVE THE ADDITIONAL AREA WILL BE REQUIRED TO EXCAVATE BY PROTECTING THE NEARBY EXISTING NG PIPELINE FOUNDATIONS TO IDENTIFY PIPELINE LEAKAGE LOCATION. IN SUCH CASE CONTRACTOR IS REQUIRED TO PROVIDE UNIT</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600444
DATE : 12.03.2026
REQ No : 1032600242
REQ TITLE : URGENT REQUIREMENT:
DELIVERY LOCATION
CLOSING DATE : 18.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>RATE OF EXCAVATION PER CUBICMETER CONSIDERING ABOVE WORK SCOPE AND SAFETY REQUIREMENT. THE PAYMENTWILL BE BASED ON ACTUAL MEASUREME NT OF THE QUANTITY AT SITE.CONTRACTOR TO PROVIDE THEIR QUOTE IN THE PRESCRIBED FORMAT BELOW.SERIAL NUMBER#WORK DESCRIPTION #UNIT OF MEASUREMENT#OFFERED PRICE1#PRICE SHALL BE QUOTED AS MENTIONED ABOVE IN A. FIX WORK SCOPEINCLUDING PRELIMINARY WORKS#LUMPSUM#2#PRICE SHALL BE QUOTED AS MENTIONED ABOVE IN B. VARIABLE WORK SCOPE#PER CUBIC METER#SITE REQUIREMENTS:1.#SINCE ALL ACTIVITIES ARE CONDUCTED WITHIN THE NATURAL GAS STATION,WHICH IS CLASSIFIED AS A HAZARDOUS AREA, ALL NECESSARY PRECAUTIONSRELATED TO SUCH ENVIRONMENTS MUST BE STRICTLY FOLLOWED.2.#ALL EXCAVATION SHALL BE DONE ONLY MANUALLY AND WITH THEPLASTIC/FIBER SHOVEL.3.#CONDUCT DAILY</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600444
DATE : 12.03.2026
REQ No : 1032600242
REQ TITLE : URGENT REQUIREMENT:
DELIVERY LOCATION
CLOSING DATE : 18.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SAFETY TOOLBOX TALKS FOR ALL PERSONNEL PRIOR TO COMMENCING WORK.4.#ENSURE ALL WORKERS ARE EQUIPPED WITH THE NECESSARY PERSONAL PROTECTIVE EQUIPMENT (PPE) SUCH AS SAFETY HELMETS, REFLECTIVE VESTS,GLOVES, SAFETY BOOTS, AND GOGGLES.5.#PROTECT PIPELINES NEAR THE EXCAVATION WITH SCAFFOLDING AND SECURE BARRICADES TO PREVENT DAMAGE TO EXISTING UTILITIES.6.#MAINTAIN A FULLY STOCKED FIRST AID BOX AND ENSURE A FIRST AID ROOM IS ACCESSIBLE ON-SITE AT ALL TIMES.7.#OBTAIN PRIOR PERMISSION FROM THE DEWA IN CHARGE BEFORE INITIATING ANY EXCAVATION OR REPAIR ACTIVITIES.8.#ASSIGN ONLY QUALIFIED, TRAINED, AND COMPETENT PERSONNEL TO PERFORM EXCAVATION. 9.#IMPLEMENT ALL NECESSARY PRECAUTIONARY AND PROTECTIVE MEASURES PRIOR TO COMMENCING THE WORK.10.#BARRICADE THE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600444
DATE : 12.03.2026
REQ No : 1032600242
REQ TITLE : URGENT REQUIREMENT:
DELIVERY LOCATION
CLOSING DATE : 18.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>WORKING AREA USING WARNING TAPES, SAFETY CONES, ANDBARRIERS TO RESTRICT UNAUTHORIZED ACCESS.11.#VERIFY THAT ALL MATERIALS, TOOLS, AND EQUIPMENT USED ARE APPROVED,CERTIFIED, AND COMPLIANT WITH PR</p> <p>OJECT SPECIFICATIONS.12.#CLEARLY MARK AND DEFINE THE EXCAVATION AREA AROUND THE DAMAGEDPIPELINE. ENSURE THAT THE EXCAVATION WIDTH IS SUFFICIENT TO PROVIDE SAFEWORKING SPACE AND PROPER ACCESS FOR PIPE REPAIR.13.#PROVIDE ADEQUATE SHORING AND BRACING AS PER THE APPROVED DESIGN ANDENGINEER#S INSTRUCTIONS TO ENSURE EXCAVATION STABILITY.14.#UPON COMPLETION OF REPAIR ACTIVITIES, REMOVE ALL SHORING, B</p> <p>ACKFILLTHE EXCAVATION TO THE ORIGINAL GROUND LEVEL, COMPACT PROPERLY, AND CLEANTHE SITE THOROUGHLY.##GENERAL SAFETY PRECAUTIONS1.#ALL DEWA SAFETY & ENVIRONMENT POLICY, RULES</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600444
DATE : 12.03.2026
REQ No : 1032600242
REQ TITLE : URGENT REQUIREMENT:
DELIVERY LOCATION
CLOSING DATE : 18.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>AND REGULATIONS SHALL BE FOLLOWED AT WORK SITE AND DEWA PREMISES DURING THE CONTRACT PERIOD . THE CONTRACTOR'S WORK WILL FALL WITHIN THE PURVIEW OF SAFETY SURVEYS CONDUCTED REGULARLY BY THE DEWA SAFETY SECTION. ALL THEIR SAFETY REQUIREMENTS SHALL BE PROMPTLY MET. 2.#THE CONTRACTOR SHALL CHECK THE CONDITION SUITABLE TO CARRY OUT THE WORK. CONDUCT SITE SURVEY AND SAFETY INSPECTION TO ASSESS THE WORKING ENVIRONMENT, PROPER ISOLATION & OTHER HAZARDS. 3.#TOOL BOX TALK (TBT) SHALL BE GIVEN BY THE CONTRACTOR SUPERVISOR TO HIS STAFFS REGARDING THE NECESSARY STEPS TO BE TAKEN FOR SAFE EXECUTION OF WORKS INCLUDING RISK ASSESSMENT CARRIED OUT PRIOR TO THE SUBMISSION OF RISK ASSESSMENT SHEETS AND START OF WORK. 4.#WELDING, FLAME HEATING OR CUTTING, GRINDING, PNEUMA</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600444
DATE : 12.03.2026
REQ No : 1032600242
REQ TITLE : URGENT REQUIREMENT:
DELIVERY LOCATION
CLOSING DATE : 18.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>TIC CHIPPING,ETC. SHALL BE CARRIED OUT ONLY ON SPECIFIC CLEARANCE FROM DEWA THROUGH"HOT WORK PERMITS". THE HOT WORK PERMIT SHALL BE OBTAINED ON DAILYBASIS.5.#THE CONTRACTOR SHALL ENSURE THAT ADEQUATE FIRE PROTECTION EQUIPMENTAND MEN ARE AVAILABLE TO FIGHT ANY POSSIBLE HAZARDS. ALL DEWA RULES ANDREGULATIONS FOR HOT WORK PERMIT SHOULD BE STRICTLY FOLLOWED.6.#RISK ASSESSMENT (RA) SHALL BE UPDATED BASED ON THE PRESENTCONDITION, ENVIRONMENT AND WORKING STAFFS ON A CASE TO CASE BASIS. RASHOULD BE MORE SPECIFIC BASED ON THE WORK ON HAND AND PREVAILINGENVIRONMENT.7.#PLANT INSTALLATIONS, INSTRUMENTS, PIPING & ELECTRICAL CABLES IN THEWORK OR ADJACENT AREA TO BE ADEQUATELY PROTECTED AGAINST DAMAGE WHILEEXECUTION OF THE CONTRACT</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600444
DATE : 12.03.2026
REQ No : 1032600242
REQ TITLE : URGENT REQUIREMENT:
DELIVERY LOCATION
CLOSING DATE : 18.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>WORK.8.#WHILE WORKING THE CONTRACTOR SHOULD BARRICADE THE AREA PR EVENTINGMOVEMENT OF PLANT OPERATORS AND MAINTENANCE PERSONNEL IN THE WORK AREA.9.#ONLY NON-SPARKING TOOLS SHOULD BE USED INCLUDING H ACK SAW, KNIFE,HAMMER AND CHISEL ETC. INSIDE NGPRS AND NG SYSTEM. THE DEWA SAFETY RULESAND REGULATIONS PERTAINING TO NG AND DFO SYST EM SHOULD BE STRICTLYFOLLOWED AND MONITORED BY THE SAFETY SUPERVISOR.10.#ALL EQUIPMENT LIKE RIGGING TOOLS, GRINDING MACHINES, DRILLI NGMACHINES, HAND TOOLS AND PRECISION TOOLS SHOULD HAVE VALID TESTCERTIFICATES FROM 3RD PARTY LICENSED CERTIFYING AGENCIES SHALL BEPR ODUCE BY THE CONTRACTOR.11.#THE CONTRACTOR SHALL CARRY OUT RISK ANALYSIS FOR ALL HIS WORKS.THIS RISK ANALYSIS SHALL BE FROM SAFETY AS WELL AS OCCUPATIONAL</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600444
DATE : 12.03.2026
REQ No : 1032600242
REQ TITLE : URGENT REQUIREMENT:
DELIVERY LOCATION
CLOSING DATE : 18.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>HEALTHCONSIDERATIONS.12.#ALL SPECIAL TOOLS, RIGGING TOOLS, INSPECTION TOOLS, TEMPORARYPLATFORMS, LADDERS, HOSES ETC., SHALL BE INSPECTED AND TESTED BYAPPROVED AUTHORITIES AND THE CONTRACTOR SHALL SUBMIT TO DEWA ON DEMANDWITH NECESSARY CERTIFICATION BEFORE THEIR USE AT SITE.13.#THE TEMPORARY OFFICE/STORES OF THE CONTRACTOR IN THE PREMISES OFDEWA SHALL BE CONSTRUCTED OF NON-FLAMMABLE MATERIAL. THE FACILITY SHALLHAVE ADEQUATE NUMBER OF HEALTHY FIRE EXTINGUISHERS FOR USE DURINGEMERGENCY SITUATIONS.14.#WELDING AND/OR OXY-ACY CYLINDER TROLLEYS, IF USED, AREA OF WELDINGAND FLAME CUTTING SHALL HAVE ADEQUATE NUMBER OF HEALTHY FIREEXTINGUISHERS, NON-ASBESTOS FLAME/HEAT BLANKETS. CYLINDERS TO BE CLOSEDWHILE NOT IN USE.15.#THE AREA OF WORK SHALL BE KEPT CLEAN AT ALL TIM</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600444
DATE : 12.03.2026
REQ No : 1032600242
REQ TITLE : URGENT REQUIREMENT:
DELIVERY LOCATION
CLOSING DATE : 18.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ES BEFORE, DURING AND AFTER T						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

URGENT REQUIREMENT: UNDERGROUND FIRE WATER PIPELINE LEAK RECTIFICATION INSIDE NATURAL GAS STATION; PHASE 1; AL AWEER. for more information and details please contact: zamir.alware zamir.alware@dewa.gov.ae 04-81-40304 +971509152946

STANDARD TERMS & CONDITIONS

- 1) RFQ Document Disclaimer: The PDF version of this Request for Quotation (RFQ) is provided for convenience only and contains a summary of key information. It does not include all technical details, requirements, or specifications. Bidders must refer to the complete system documentation and all referenced materials to obtain full and accurate information necessary for preparing their proposals.
- 2) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 3) Quotation to be submitted only in local currency U.A.E Dirhams
- 4) DEWA Standard Payments: Payment will be made within 30 days from the date the Supplier/Contractor submits a complete and accurate invoice, together with all required supporting documents, subject to the material and/or services having been duly accepted.
- 5) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER	: 2412600444
DATE	: 12.03.2026
REQ No	: 1032600242
REQ TITLE	: URGENT REQUIREMENT:
DELIVERY LOCATION	
CLOSING DATE	: 18.03.2026
CLOSING TIME	: 10:00:00

6) The offered product and/or services in the Quotation, shall be confirming and in accordance with DEWA Energy Management Policy & EnMS Manual.

7) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer. If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements. The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

8) Data Privacy, Security and Sharing:

a) Third-party shall handle DEWA data in accordance with all applicable laws, regulations, and DEWA policies.

b) DEWA data shall not be shared outside UAE, in line with DESC ISR requirements.

c) DEWA's Non-Disclosure Agreement (NDA) and External Party Acknowledgment (EPA) shall be signed by the third-party and their sub-contractors who handle DEWA data prior to the contract commencement.

d) DEWA reserves the right to withhold data from third parties if deemed sensitive.

e) Access to data must be restricted to authorized, named third-party employees only and DEWA must be informed of any changes in employment status of those with access.

f) Third party shall not disclose, transfer or share any DEWA data with other third parties (government, semi government, private) without obtaining DEWA's authorized data owner written approval.

g) Upon the completion/ termination of the agreement the external party shall securely delete all DEWA's data in their custody/ control including the backup and provide written confirmation and evidence to DEWA upon the data deletion completion as per agreed data disposal process, this is to address risk of data remanence.

9) Liquidated Damages for PO total value in excess of AED 50,000:

If the Contractor/Supplier delays or fails to deliver, fails to commence or perform the services, DEWA has the right to deduct an amount equal to 1.25% per day/week of the total PO fee for the services/supplies delayed, not performed or not delivered, subject to a cap of 10% of the total PO fee without recourse to any judicial proceedings, as compensation for the delay or failure to perform. If the deducted amount exceeds 10% of the total PO fee, without prejudice to any of DEWA's rights under the applicable law, DEWA shall be entitled to terminate the PO immediately without the need for any notice or judicial proceedings against the defaulting Supplier, and without the need to prove the damage.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600444
DATE : 12.03.2026
REQ No : 1032600242
REQ TITLE : URGENT REQUIREMENT:
DELIVERY LOCATION
CLOSING DATE : 18.03.2026
CLOSING TIME : 10:00:00

- 10) Indemnity: The Supplier shall indemnify DEWA from and against all claims, damages, costs and liabilities brought by any third party against DEWA arising out of or in connection with any of acts or omissions of the Supplier/Contractor, or any failure to perform its obligations under this PO.
- 11) Dispute Resolution: Any dispute arising out of or in connection with this PO shall be settled through mutual good faith negotiation and understanding between the Parties: Failing amicable settlement, the dispute shall finally be referred to the courts having appropriate jurisdiction in the Emirate of Dubai.
- 12) Intellectual Property Rights: The Supplier/Contractor shall not use DEWA's intellectual property, including logos, trademarks, service marks, trade names, service names, and brand names, whether in a press release or otherwise, without obtaining DEWA's prior written consent. All intellectual property rights in the deliverables created or developed, under this PO, shall be solely owned by DEWA.
- 13) Assignment and Transfer: The Supplier/Contractor shall not assign this PO or any part thereof without the prior written consent of DEWA. Such consent shall not relieve the Contractor of any of its obligations or duties under this PO.
- 14) Force Majeure: If either party is affected by a Force Majeure event, it will promptly notify the other party of the nature and extent thereof. Neither party will be deemed to be in breach of this PO, by reason of any delay or non-performance, of any of its obligations hereunder, due to any Force Majeure event of which it has notified the other party. The time for performance of these obligations will be extended accordingly as may be fair and reasonable in the circumstances. Provided always that if the duration of such delay or impediment exceeds thirty (30) days, either party may give a fifteen (15) working days' notice to terminate a specific item or the PO in its entirety.
- 15) Certificate of Conformity for Green Materials and Services Specifications: The Bidder shall, wherever applicable, provide a Certificate of conformity issued by accredited body/ laboratory as proof of compliance with the applicable green materials, services and specifications.
- 16) Taking Over Certificate: TOC shall be issued only after full delivery or completion of the service or deliverables. TOC will be issued conditionally ("conditional TOC") with the reasonable guarantee/observation in case of any defects after delivery or completion of the PO.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600444
DATE : 12.03.2026
REQ No : 1032600242
REQ TITLE : URGENT REQUIREMENT:
DELIVERY LOCATION
CLOSING DATE : 18.03.2026
CLOSING TIME : 10:00:00

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP