

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412601426
DATE : 24.08.2026
REQ No : 1012602514
REQ TITLE : 1012602514 SPARES FOR
DELIVERY LOCATION : 0017 - L1 STORES, JAPS
CLOSING DATE : 31.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1	3700037346		BALL. BALL FOR TRUNNION MOUNTED, GEAR OPERATED, FIRE SAFE BALL VALVEWITH BLOW OUT PROOF STEM DESIGN. SIZE - DN 650 26". CLASS - 150. MODEL -CFA15-AG650. SERIAL NUMBERS - KC0547, KC0548, KC0549 & KC0550.#MANUFACTURER - KVC CO., LTD. MAXIMUM OPERATING PRESSURE - 19. 6 BAR AT 38DEGREE CELSIUS. VALVE DESIGN ACCORDING TO ASME B16.34. FACE TO FACEDIMENSION ACCORDING TO ASME B16.10. END FLANGE DIMENSI ONS ACCORDING TOASME B16.47 RF. FIRE SAFE ACCORDING TO API 607. ANTI STATIC DEVICE : BS5351. NACE MR-01-75. ISO 5211 MOUNTING PAD. D RAIN & VENT PLUG: NPT 1".BALL MATERIAL - A351-CF8. PART NUMBER - 3. VALVE FACE TO FACE DIMENSION- 1143 MM. PCD - 806.5 MM. MEDIUM - DFO. APPLICATION - DFO BULK TRANFERFILTER & PUMP COMMON INLET AND OUTLET ISOLATION. KKS NO - 70EGD14AA030,70EGD14AA131, 70EGD14AA210 & 70EGD14AA231.	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412601426
DATE : 24.08.2026
REQ No : 1012602514
REQ TITLE : 1012602514 SPARES FOR
DELIVERY LOCATION : 0017 - L1 STORES, JAPS
CLOSING DATE : 31.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
2	3700037347		STEM. STEM FOR TRUNNION MOUNTED, GEAR OPERATED, FIRE SAFE BALL VALVEWITH BLOW OUT PROOF STEM DESIGN. SIZE - DN 650 26". CLASS - 150. MODEL -CFA15-AG650. SERIAL NUMBERS - KC0547, KC0548, KC0549 & KC0550.#MANUFACTURER - KVC CO., LTD. MAXIMUM OPERATING PRESSURE - 19. 6 BAR AT 38DEGREE CELSIUS. VALVE DESIGN ACCORDING TO ASME B16.34. FACE TO FACEDIMENSION ACCORDING TO ASME B16.10. END FLANGE DIMENSI ONS ACCORDING TOASME B16.47 RF. FIRE SAFE ACCORDING TO API 607. ANTI STATIC DEVICE : BS5351. NACE MR-01-75. ISO 5211 MOUNTING PAD. D RAIN & VENT PLUG: NPT 1".STEM MATERIAL - A276-304. PART NUMBER - 4. VALVE FACE TO FACE DIMENSION- 1143 MM. PCD - 806.5 MM. MEDIUM - DFO. APPLICATION - DFO BULK TRANFERFILTER & PUMP COMMON INLET AND OUTLET ISOLATION. KKS NO - 70EGD14AA030,70EGD14AA131, 70EGD14AA210 & 70EGD14AA231.	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412601426
DATE : 24.08.2026
REQ No : 1012602514
REQ TITLE : 1012602514 SPARES FOR
DELIVERY LOCATION : 0017 - L1 STORES, JAPS
CLOSING DATE : 31.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
3	3700037348		LOWER STEM. LOWER STEM FOR TRUNNION MOUNTED, GEAR OPERATED, FIRE SAFEBALL VALVE WITH BLOW OUT PROOF STEM DESIGN. SIZE - DN 650 26". CLASS -150. MODEL - CFA15-AG650. SERIAL NUMBERS - KC0547, KC0548, KC0549 & KC0550.# MANUFACTURER - KVC CO., LTD. MAXIMUM OPERATING PR ESSURE - 19.6BAR AT 38 DEGREE CELSIUS. VALVE DESIGN ACCORDING TO ASME B16.34. FACE TOFACE DIMENSION ACCORDING TO ASME B16.10. END FL ANGE DIMENSIONS ACCORDING TO ASME B16.47 RF. FIRE SAFE ACCORDING TO API 607. ANTI STATIC DEVICE :BS 5351. NACE MR-01-75. ISO 5211 MOU NTING PAD. DRAIN & VENT PLUG: NPT1". LOWER STEM MATERIAL - A276-304. PART NUMBER - 5. VALVE FACE TO FACEDIMENSION - 1143 MM. PCD - 8 06.5 MM. MEDIUM - DFO. APPLICATION - DFOBULK TRANFER FILTER & PUMP COMMON INLET AND OUTLET ISOLATION. KKS NO -70EGD14AA030,	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412601426
DATE : 24.08.2026
REQ No : 1012602514
REQ TITLE : 1012602514 SPARES FOR
DELIVERY LOCATION : 0017 - L1 STORES, JAPS
CLOSING DATE : 31.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			70EGD14A A131, 70EGD14AA210 & 70EGD14AA231.						
4	3700037349		SEAT. BALL SEAT SET FOR TRUNNION MOUNTED, GEAR OPERATED, FIRE SAFE BALLVALVE WITH BLOW OUT PROOF STEM DESIGN. SIZE - DN 650 26". CLA SS - 150.MODEL - CFA15-AG650. SERIAL NUMBERS - KC0547, KC0548, KC0549 & KC0550.#MANUFACTURER - KVC CO., LTD. MAXIMUM OPERATING PRESS URE - 19.6 BAR AT 38DEGREE CELSIUS. VALVE DESIGN ACCORDING TO ASME B16.34. FACE TO FACEDIMENSION ACCORDING TO ASME B16.10. END FLANG E DIMENSIONS ACCORDING TOASME B16.47 RF. FIRE SAFE ACCORDING TO API 607. ANTI STATIC DEVICE : BS5351. NACE MR-01-75. ISO 5211 MOUNTI NG PAD. DRAIN & VENT PLUG: NPT 1".BALL SEAT MATERIAL - PTFE. PART NUMBER - 10. VALVE FACE TO FACEDIMENSION - 1143 MM. PCD - 806.5 MM . MEDIUM - DFO. APPLICATION - DFOBULK TRANFER FILTER & PUMP COMMON INLET AND OUTLET ISOLATION. KKS NO -70EGD14AA030,	1	SET				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412601426
DATE : 24.08.2026
REQ No : 1012602514
REQ TITLE : 1012602514 SPARES FOR
DELIVERY LOCATION : 0017 - L1 STORES, JAPS
CLOSING DATE : 31.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			70EGD14AA131, 7 0EGD14AA210 & 70EGD14AA231.						
5	3700037350		SPRING. SPRING SET FOR TRUNNION MOUNTED, GEAR OPERATED, FIRE SAFE BALLVALVE WITH BLOW OUT PROOF STEM DESIGN. SIZE - DN 650 26". CLAS S - 150.MODEL - CFA15-AG650. SERIAL NUMBERS - KC0547, KC0548, KC0549 & KC0550.#MANUFACTURER - KVC CO., LTD. MAXIMUM OPERATING PRESSU RE - 19.6 BAR AT 38DEGREE CELSIUS. VALVE DESIGN ACCORDING TO ASME B16.34. FACE TO FACEDIMENSION ACCORDING TO ASME B16.10. END FLANGE DIMENSIONS ACCORDING TOASME B16.47 RF. FIRE SAFE ACCORDING TO API 607. ANTI STATIC DEVICE : BS5351. NACE MR-01-75. ISO 5211 MOUNTIN G PAD. DRAIN & VENT PLUG: NPT 1".SPRING MATERIAL - INCONEL X-750. PART NUMBER - 54. VALVE FACE TO FACEDIMENSION - 1143 MM. PCD - 806 .5 MM. MEDIUM - DFO. APPLICATION - DFOBULK TRANFER FILTER & PUMP COMMON INLET AND	1	SET				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412601426
DATE : 24.08.2026
REQ No : 1012602514
REQ TITLE : 1012602514 SPARES FOR
DELIVERY LOCATION : 0017 - L1 STORES, JAPS
CLOSING DATE : 31.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			OUTLET ISOLATION. KKS NO -70EGD14AA030, 70EGD14AA1 31, 70EGD14AA210 & 70EGD14AA231.						
6	3700037351		REPAIR KIT. REPAIR KIT FOR TRUNNION MOUNTED, GEAR OPERATED, FIRE SAFE BALL VALVE WITH BLOW OUT PROOF STEM DESIGN. SIZE - DN 650 26". CLASS -150. MODEL - CFA15-AG650. SERIAL NUMBERS - KC0547, KC0548, KC0549 & KC0550.# MANUFACTURER - KVC CO., LTD. MAXIMUM OPERATING PRESSURE - 19.6BAR AT 38 DEGREE CELSIUS. VALVE DESIGN ACCORDING TO ASME B16.34. FACE TO FACE DIMENSION ACCORDING TO ASME B16.10. END FLANGE DIMENSIONS ACCORDING TO ASME B16.47 RF. FIRE SAFE ACCORDING TO API 607. ANTI STATIC DEVICE :BS 5351. NACE MR-01-75. ISO 5211 MOU NTING PAD. DRAIN & VENT PLUG: NPT1". REPAIR KIT INCLUDES PACKING (PART NUMBER 11), GASKET A (PART NUMBER 12), GASKET B (PART NUMBER 13), PAD BEARING (PART NUMBER 15),	1	SET				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412601426
DATE : 24.08.2026
REQ No : 1012602514
REQ TITLE : 1012602514 SPARES FOR
DELIVERY LOCATION : 0017 - L1 STORES, JAPS
CLOSING DATE : 31.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			STEMBEARING (PART NUMBER 17), TRUNNION BEARING (PART NUMBER 18), THRUSTBEARING B (PART NUMBER 20), RETAINER SEAL (PART NUMBER 24), O RINGSA,B,C,D & C (PART NUMBERS 42,43,44,46 & 47), ANTI STATIC SPRING & BALL(PART NUMBERS 57 & 58) .. VALVE FACE TO FACE DIMENSION - 1143 MM. PCD -806.5 MM. MEDIUM - DFO. APPLICATION - DFO BULK TRANFER FILTER & PUMPCOMMON INLET AND OUTLET ISOLATION. KKS NO - 70EGD14AA030, 70EGD14AA131,70EGD14AA210 & 70EGD14AA231.						
7	3700037412		REPAIR KIT. REPAIR KIT FOR MOTOR OPERATED BALL VALVE . TYPE - TRUNNIONMOUNTED, ELECTRIC ACTUATOR OPERATED, FIRE SAFE WITH BLOW OUT P ROOF STEM.SIZE - DN 650 26". CLASS - 150. MODEL - CFA15-AG650. DRAWING NO:CHA-WSIAM-2-1. SERIAL NUMBER - KC0548. MANUFACTURER - KVC CO., LTD.MAXIMUM OPERATING PRESSURE - 19.6 BAR AT 38 DEGREE CELSIUS. VALVE DESIGNACCORDING TO ASME B16.34. FACE TO	1	SET				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412601426
DATE : 24.08.2026
REQ No : 1012602514
REQ TITLE : 1012602514 SPARES FOR
DELIVERY LOCATION : 0017 - L1 STORES, JAPS
CLOSING DATE : 31.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			FACE DIMENS ION ACCORDING TO ASMEB16.10. END FLANGE DIMENSIONS ACCORDING TO ASME B16.47 RF. FIRE SAFEACCORDING TO						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

SPARES FOR BALL VALVE (MOV and HOV), DFO SYSTEM L1 STATION drawing/nameplate details attached

STANDARD TERMS & CONDITIONS

- 1) RFQ Document Disclaimer: The PDF version of this Request for Quotation (RFQ) is provided for convenience only and contains a summary of key information. It does not include all technical details, requirements, or specifications. Bidders must refer to the complete system documentation and all referenced materials to obtain full and accurate information necessary for preparing their proposals.
- 2) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 3) Quotation to be submitted only in local currency U.A.E Dirhams
- 4) DEWA Standard Payments: Payment will be made within 30 days from the date the Supplier/Contractor submits a complete and accurate invoice, together with all required supporting documents, subject to the material and/or services having been duly accepted.
- 5) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER	: 2412601426
DATE	: 24.08.2026
REQ No	: 1012602514
REQ TITLE	: 1012602514 SPARES FOR
DELIVERY LOCATION	: 0017 - L1 STORES, JAPS
CLOSING DATE	: 31.08.2026
CLOSING TIME	: 10:00:00

6) The offered product and/or services in the Quotation, shall be confirming and in accordance with DEWA Energy Management Policy & EnMS Manual.

7) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer. If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements. The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

8)Data Privacy, Security and Sharing:

- a) Third-party shall handle DEWA data in accordance with all applicable laws, regulations, and DEWA policies.
- b) DEWA data shall not be shared outside UAE, in line with DESC ISR requirements.
- c) DEWA's Non-Disclosure Agreement (NDA) and External Party Acknowledgment (EPA) shall be signed by the third-party and their sub-contractors who handle DEWA data prior to the contract commencement.
- d) DEWA reserves the right to withhold data from third parties if deemed sensitive.
- e) Access to data must be restricted to authorized, named third-party employees only and DEWA must be informed of any changes in employment status of those with access.
- f) Third party shall not disclose, transfer or share any DEWA data with other third parties (government, semi government, private) without obtaining DEWA's authorized data owner written approval.
- g) Upon the completion/ termination of the agreement the external party shall securely delete all DEWA's data in their custody/ control including the backup and provide written confirmation and evidence to DEWA upon the data deletion completion as per agreed data disposal process, this is to address risk of data remanence.

9) Liquidated Damages for PO total value in excess of AED 50,000:

If the Contractor/Supplier delays or fails to deliver, fails to commence or perform the services, DEWA has the right to deduct an amount equal to 1.25% per day/week of the total PO fee for the services/supplies delayed, not performed or not delivered, subject to a cap of 10% of the total PO fee without recourse to any judicial proceedings, as compensation for the delay or failure to perform. If the deducted amount exceeds 10% of the total PO fee, without prejudice to any of DEWA's rights under the applicable law, DEWA shall be entitled to terminate the PO immediately without the need for

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER	: 2412601426
DATE	: 24.08.2026
REQ No	: 1012602514
REQ TITLE	: 1012602514 SPARES FOR
DELIVERY LOCATION	: 0017 - L1 STORES, JAPS
CLOSING DATE	: 31.08.2026
CLOSING TIME	: 10:00:00

any notice or judicial proceedings against the defaulting Supplier, and without the need to prove the damage.

10) Indemnity: The Supplier shall indemnify DEWA from and against all claims, damages, costs and liabilities brought by any third party against DEWA arising out of or in connection with any of acts or omissions of the Supplier/Contractor, or any failure to perform its obligations under this PO.

11) Dispute Resolution: Any dispute arising out of or in connection with this PO shall be settled through mutual good faith negotiation and understanding between the Parties: Failing amicable settlement, the dispute shall finally be referred to the courts having appropriate jurisdiction in the Emirate of Dubai.

12) Intellectual Property Rights: The Supplier/Contractor shall not use DEWA's intellectual property, including logos, trademarks, service marks, trade names, service names, and brand names, whether in a press release or otherwise, without obtaining DEWA's prior written consent. All intellectual property rights in the deliverables created or developed, under this PO, shall be solely owned by DEWA.

13) Assignment and Transfer: The Supplier/Contractor shall not assign this PO or any part thereof without the prior written consent of DEWA. Such consent shall not relieve the Contractor of any of its obligations or duties under this PO.

14) Force Majeure: If either party is affected by a Force Majeure event, it will promptly notify the other party of the nature and extent thereof. Neither party will be deemed to be in breach of this PO, by reason of any delay or non-performance, of any of its obligations hereunder, due to any Force Majeure event of which it has notified the other party. The time for performance of these obligations will be extended accordingly as may be fair and reasonable in the circumstances. Provided always that if the duration of such delay or impediment exceeds thirty (30) days, either party may give a fifteen (15) working days' notice to terminate a specific item or the PO in its entirety.

15) Certificate of Conformity for Green Materials and Services Specifications: The Bidder shall, wherever applicable, provide a Certificate of conformity issued by accredited body/ laboratory as proof of compliance with the applicable green materials, services and specifications.

16) Taking Over Certificate: TOC shall be issued only after full delivery or completion of the service or deliverables. TOC will be issued conditionally ("conditional TOC") with the reasonable guarantee/observation in case of any defects after delivery or completion of the PO.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412601426
DATE : 24.08.2026
REQ No : 1012602514
REQ TITLE : 1012602514 SPARES FOR
DELIVERY LOCATION : 0017 - L1 STORES, JAPS
CLOSING DATE : 31.08.2026
CLOSING TIME : 10:00:00

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP