

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2492600117
DATE : 19.02.2026
REQ No : 1172600101
REQ TITLE : Supply & Installation of 6 x
DELIVERY LOCATION : 0022 - M STORES, JAPS
CLOSING DATE : 25.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE	
1	7000000011		SUPPLY & INSTALLATION OF 6 X 2.5TR SPLIT AC UNITS (EXPLOSION PROOF) FOR LOCAL ELECTRONIC ROOMS IN GAS COMPRESSOR STATIONS -10, 20 & 30 ATM-STATIONS (2 NOS. IN EACH BLOCK). SPLIT A/C 2.5 TONS EXPLOSION-PROOF AIR CONDITIONER EXPLOSION-PROOF MARK: II 2 G D EX DB IB MB I IC T4 GB VOLTAGE & FREQUENCY: 220/ 380VAC, 50HZ REFRIGERANT: HFC REFRIGERANT. MAKE: O-GENERAL/ MITSUBISHI/ SG/ LEIZURSCOPE OF WORK: 1 ALL THE REFRIGERANT PIPING SHALL BE INSULATED AND LAID IN GI TRUNKING FOR OUTDOOR AREA AND PVC TRUNKING FOR INDOOR AREA. 2) CONTROL CABLES FROM INDOOR TO OUTDOOR UNIT SHALL BE LAID IN GI CONDUIT. 3) ELECTRICAL POWER SUPPLY SHALL BE TAKEN FROM THE NEAREST DISTRIBUTION PANEL. POWER SUPPLY FROM DB TO ISOLATOR AND ISOLATOR TO UNIT IS THE CONTRACTOR RESPONSIBILITY. THE CABLE SHALL BE LAID IN	6	EA					

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2492600117
DATE : 19.02.2026
REQ No : 1172600101
REQ TITLE : Supply & Installation of 6 x
DELIVERY LOCATION : 0022 - M STORES, JAPS
CLOSING DATE : 25.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			COPEX/ GI C ONDUIT.4) ISOLATOR SHALL BE OF EXPLOSION PROOF.5) CONTROL AND POWER CABLE SHOULD BE FIRE RATED AND SUITABLE FOR EXPLOSION ENVIRONMENT .6) POWER CABLE FROM DISTRIBUTION PANEL TO LOCAL ISOLATOR AND FROM ISOLATOR TO THE OUTDOOR UNIT SHALL BE LAID IN GI CONDUIT .7) PVC D RAIN SHALL BE INSULATED & FOSTERED, AND TO BE ROUTED TO THE NEAREST DRAIN POINT.8) OUTDOOR UNIT SHALL BE MOUNTED ON GI FRAME/ CONCRETE E FOUNDATION. THE FRAME SHALL BE PAINTED WITH ANTI-CORROSIVE PAINT/ CONCRETE BLOCK SHALL BE PLASTERED AND PAINTED.9) CORE DRILLING SHALL BE DONE AT ALL WALL CROSSINGS FOR ROUTING THE REFRIGERANT & DRAIN LINES AND CABLES. ALL SUCH OPENINGS SHALL BE SEALED PROPERLY.10) IDENTIFICATION TAGS SHALL BE INSTALLED FOR THE INDOOR & OUTDOOR AC UNITS, ALL CABLES						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2492600117
DATE : 19.02.2026
REQ No : 1172600101
REQ TITLE : Supply & Installation of 6 x
DELIVERY LOCATION : 0022 - M STORES, JAPS
CLOSING DATE : 25.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>AND TRUNK/CONDUITS.11) EARTHING SHALL BE DONE CONTINUOUSLY AT ALL JOINTS OF CONDUIT/TRUNKS. OUTDOOR A/C UNITS SHALL BE EARTHED PROPERLY.12) TESTING & COMMISSIONING OF THE UNITS SHALL BE COMPLETED BEFORE MAY2026.13) THE FOLLOWING DOCUMENTS SHALL BE SUBMITTED AT THE TIME OF DELIVERY: A) CERTIFICATE OF WARRANTY FOR 1 YEAR FOR THE A/C UNITS AND FOR 5 YEARS FOR THE COMPRESSORS. B) O&M MANUAL AND CONTROL CIRCUIT DRAWINGS OF THE UNITS.14) CONTRACTOR SHALL VISIT DEWA M-STATION SITE, TO FAMILIARIZE WITH SITE LAYOUT AND REQUIREMENTS, BEFORE QUOTING. FOR ANY CLARIFICATION, PLEASE CONTACT MR. MUMTAZ (04-3225864/ 055-6471260). EMAIL: MUMTAZ.ABRO@DEWA.GOV.AE</p> <p>NOTE: 1. ALL THE NON SPARKING TOOLS AND EQUIPMENT SHALL BE USED TO WORK IN GAS AREA DURING THE INSTALLATION &</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2492600117
DATE : 19.02.2026
REQ No : 1172600101
REQ TITLE : Supply & Installation of 6 x
DELIVERY LOCATION : 0022 - M STORES, JAPS
CLOSING DATE : 25.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			COMMISSIONING.2. CONTRACTOR HAS TO OBTAIN PRIOR APPROVAL FROM DEWA ENGINEER FOR ALL THE SITE INSTALLATION LIKE INSULATION, REFRIGERANT PIPE, COPEX, TRUNKING, GI CONDUIT, ETC.3. CONTRACTOR SHALL INCLUDE IN THEIR SCOPE FOR ANYTHING MISSED ABOVE BUT NECESSARILY REQUIRED TO COMPLETE THE INSTALLATION JOBS FOR THE 100% COMPLIANCE TO THE APPLICABLE STANDARDS.						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

Supply <(>&<>) Installation of 6 x 2.5TR Split AC units (Explosion Proof) for Local Electronic Rooms in Gas Compressor Stations -10, 20 <(>&<>) 30 at M-Stations (2 nos. in each block).

STANDARD TERMS & CONDITIONS

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER	: 2492600117
DATE	: 19.02.2026
REQ No	: 1172600101
REQ TITLE	: Supply & Installation of 6 x
DELIVERY LOCATION	: 0022 - M STORES, JAPS
CLOSING DATE	: 25.02.2026
CLOSING TIME	: 10:00:00

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.
- 6) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer.

If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements

The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP