

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2492600549
DATE : 09.09.2026
REQ No : 1172600795
REQ TITLE : 1 Portable Capacitance Bridge
DELIVERY LOCATION : 0051 - CS WRSN, TRNSMSN
CLOSING DATE : 15.09.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1	7000000014		PORTABLE CAPACITANCE BRIDGE METER CB-2000TYPE: PORTABLE CAPACITANCE BRIDGE METER CB-2000 IS SUITABLE FOR FIELDMEASUREMENT OF SVC CAP ACITOR BANKS, FILTER CAPACITOR BANKS, ANDINDIVIDUAL CAPACITOR UNITS DURING SVC MAINTENANCE ACTIVITIES.APPLICATION: REQUIRED FOR MEAS URING CAPACITANCE OF POWER CAPACITORBANKS, INDIVIDUAL CAPACITOR UNITS, AND CAPACITOR ASSEMBLIES DURINGMAINTENANCE, INSPECTION, TROUB LESHOOTING, AND COMMISSIONING ACTIVITIES.MEASUREMENT PRINCIPLE: 4-WIRE MEASUREMENT PRINCIPLE SHALL BE USED TOENSURE ACCURATE CAPACIT ANCE MEASUREMENT AND MINIMIZE THE INFLUENCE OFTEST LEADS AND CONTACT RESISTANCE.MEASUREMENT VOLTAGE: APPROXIMATELY 111.86 HZ, 1.4 VA C, OR EQUIVALENTSUITABLE LOW-VOLTAGE TEST SIGNAL PROVIDING EQUIVALENT OR BETTERMEASUREMENT	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2492600549
DATE : 09.09.2026
REQ No : 1172600795
REQ TITLE : 1 Portable Capacitance Bridge
DELIVERY LOCATION : 0051 - CS WRSN, TRNSMSN
CLOSING DATE : 15.09.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			PERFORMANCE.MEASURING RANGES: MINIMUM MEASURING RANGES SHALL INCLUDE 20 #F, 200 #F, AND 2000 #F, OR EQUIVALENT RANGES COVERING CAPACITANCE MEASUREMENT UP TO AT LEAST 2000 #F.D DISPLAY RANGE: THE INSTRUMENT SHALL PROVIDE SUITABLE DISPLAY RANGES CORRESPONDING TO THE OFFERED MEASUREMENT RANGES, COVERING CAPACITANCE MEASUREMENT UP TO AT LEAST 1000 #F.ACCURACY: $\pm 1\%$ OF READING ± 2 DIGITS ALONG WITH DECIMAL OR BETTER.DISPLAY UNIT: DIGITAL DISPLAY UNIT WITH CLEAR CAPACITANCE INDICATION IN #F, SUITABLE RANGE SELECTION, CALIBRATION FUNCTION, POWER ON/OFF CONTROL, AND BATTERY/CHARGING INDICATION.GENERATOR UNIT: SEPARATE GENERATOR UNIT SHALL BE PROVIDED FOR SUPPLYING THE REQUIRED MEASUREMENT VOLTAGE TO THE CAPACITOR UNIT.SUPPLY OR BANK OR INDIVIDUAL CAPACITOR UNIT.SUPPLY						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2492600549
DATE : 09.09.2026
REQ No : 1172600795
REQ TITLE : 1 Portable Capacitance Bridge
DELIVERY LOCATION : 0051 - CS WRSN, TRNSMSN
CLOSING DATE : 15.09.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			CAPACITY: GENERATOR UNIT SHALL BE SUITABLE FOR CAPACITANCE MEASUREMENT UP TO A MINIMUM OF 2000 #F. CURRENT CLAMP: SUITABLE CURRENT CLAMP SHALL BE PROVIDED FOR MEASUREMENT OF CAPACITOR CURRENT DURING CAPACITANCE MEASUREMENT. POWER SUPPLY: BATTERY-OPERATED PORTABLE INSTRUMENT WITH MAINTENANCE-FREE RECHARGEABLE BATTERIES OR EQUIVALENT. BATTERY CHARGER: SUITABLE BATTERY CHARGER SHALL BE PROVIDED AND SHALL BE COMPATIBLE WITH UAE 230 VAC, 50 HZ POWER SUPPLY. OPERATING TIME: MORE THAN 8 HOURS OR BETTER WITH FULLY CHARGED BATTERIES UNDER NORMAL OPERATING CONDITIONS. CHARGING TIME: MAXIMUM 4 HOURS FOR FULLY DISCHARGED BATTERIES. OPERATING TEMPERATURE: SUITABLE FOR FIELD OPERATION FROM -10°C TO +50°C OR WIDER RANGE. PORTABILITY: COMPACT PORTABLE DESIGN WITH RUGG						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2492600549
DATE : 09.09.2026
REQ No : 1172600795
REQ TITLE : 1 Portable Capacitance Bridge
DELIVERY LOCATION : 0051 - CS WRSN, TRNSMSN
CLOSING DATE : 15.09.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ED CARRYING CASE SUITABLEFOR TRANSPORTATION AND USE IN SUBSTATION/SITE ENVIRONMENTS.DIMENSIONS AND WEIGHT: SUPPLIER SHALL CLEARLY SP ECIFY THE DIMENSIONS ANDWEIGHT OF THE DISPLAY UNIT, GENERATOR UNIT, CURRENT CLAMP, AND CARRYINGCASE.COMPLIANCE: INSTRUMENT SHALL COM PLY WITH APPLICABLE IEC/EN SAFETY ANDEMC REQUIREMENTS FOR ELECTRICAL MEASURING EQUIPMENT, INCLUDING IEC61010-1 AND IEC 61326-1, OR E QUIVALENT INTERNATIONALLY RECOGNIZEDSTANDARDS.WARRANTY: MINIMUM 2-YEAR WARRANTY SHALL BE PROVIDED FOR THE COMPLETEINSTRUMENT.ACCESSO RIES (MANDATORY)DISPLAY UNIT WITH ALL REQUIRED FUNCTIONS FOR CAPACITANCE MEASUREMENT.GENERATOR UNIT WITH VOLTAGE CLIPS/TEST LEADS FO R SUPPLYING THEMEASUREMENT VOLTAGE.SUITABLE CURRENT CLAMP.COMPLETE SET OF MEASUREMENT CABLES, VOLTAGE CLIPS,						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2492600549
DATE : 09.09.2026
REQ No : 1172600795
REQ TITLE : 1 Portable Capacitance Bridge
DELIVERY LOCATION : 0051 - CS WRSN, TRNSMSN
CLOSING DATE : 15.09.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			CONNECTORS, ADAPTORS, AND CLAMPS REQUIRED FOR THE MEASUREMENT. BATTERY CHARGER SUITABLE FOR UAE POWER SUPPLY WITH UAE-COMPATIBLE PLUG. RUGGED CARRYING CASE SUITABLE FOR TRANSPORTING AND PROTECTING THE COMPLETE INSTRUMENT AND ACCESSORIES. OPERATION MANUAL, SERVICE MANUAL, CALIBRATION PROCEDURE/INSTRUCTIONS, AND SPARE PARTS LIST. GENERAL (MANDATORY) THE INSTRUMENT SHALL BE SUPPLIED IN COMPLETE READY-TO-USE CONDITION WITH ALL REQUIRED UNITS, ACCESSORIES, TEST LEADS, BATTERIES, CHARGER, AND CARRYING CASE. FACTORY CALIBRATION CERTIFICATE TRACEABLE TO RECOGNIZED NATIONAL OR INTERNATIONAL STANDARDS SHALL BE PROVIDED. MANUFACTURER'S ROUTINE TEST CERTIFICATE AND CERTIFICATE/DECLARATION OF CONFORMITY SHALL BE PROVIDED. ALL CONTROLS, CONNECTORS, TERMINALS, POLARITY MARKINGS,						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2492600549
DATE : 09.09.2026
REQ No : 1172600795
REQ TITLE : 1 Portable Capacitance Bridge
DELIVERY LOCATION : 0051 - CS WRSN, TRNSMSN
CLOSING DATE : 15.09.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			AND WARNING LABELS SHALL BE CLEARLY IDENTIFIED ON THE INSTRUMENT. SUPPLIER SHALL CONFIRM AVAILABILITY OF AFTER-SALES SUPPORT, CALIBRATION SUPPORT, AND SPARE PARTS FOR THE OFFERED MODEL. SUPPLIER SHALL SUBMIT A CLAUSE-BY-CLAUSE COMPLIANCE STATEMENT AND CLEARLY IDENTIFY ANY DEVIATIONS FROM THIS SPECIFICATION. SUITABILITY SUITABLE FOR CAPACITANCE MEASUREMENT OF MV/HV CAPACITOR BANKS AND INDIVIDUAL CAPACITOR UNITS DURING PREVENTIVE MAINTENANCE OF SVC. SUITABLE FOR USE IN SUBSTATION/SITE ENVIRONMENTS BY MAINTENANCE PERSONNEL. SITE DEMONSTRATION OF THE OFFERED INSTRUMENT SHALL BE PROVIDED DURING THE TENDER STAGE, IF REQUESTED BY DEWA. SUPPLIER SHALL PROVIDE SITE TRAINING AFTER DELIVERY.						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER	: 2492600549
DATE	: 09.09.2026
REQ No	: 1172600795
REQ TITLE	: 1 Portable Capacitance Bridge
DELIVERY LOCATION	: 0051 - CS WRSN, TRNSMSN
CLOSING DATE	: 15.09.2026
CLOSING TIME	: 10:00:00

SPECIAL NOTES / INSTRUCTIONS:

1 Portable Capacitance Bridge Meter CB-2000

STANDARD TERMS & CONDITIONS

- 1) RFQ Document Disclaimer: The PDF version of this Request for Quotation (RFQ) is provided for convenience only and contains a summary of key information. It does not include all technical details, requirements, or specifications. Bidders must refer to the complete system documentation and all referenced materials to obtain full and accurate information necessary for preparing their proposals.
- 2) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 3) Quotation to be submitted only in local currency U.A.E Dirhams
- 4) DEWA Standard Payments: Payment will be made within 30 days from the date the Supplier/Contractor submits a complete and accurate invoice, together with all required supporting documents, subject to the material and/or services having been duly accepted.
- 5) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 6) The offered product and/or services in the Quotation, shall be confirming and in accordance with DEWA Energy Management Policy & EnMS Manual.
- 7) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer. If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements. The

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER	: 2492600549
DATE	: 09.09.2026
REQ No	: 1172600795
REQ TITLE	: 1 Portable Capacitance Bridge
DELIVERY LOCATION	: 0051 - CS WRSN, TRNSMSN
CLOSING DATE	: 15.09.2026
CLOSING TIME	: 10:00:00

Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

8) Data Privacy, Security and Sharing:

- Third-party shall handle DEWA data in accordance with all applicable laws, regulations, and DEWA policies.
- DEWA data shall not be shared outside UAE, in line with DESC ISR requirements.
- DEWA's Non-Disclosure Agreement (NDA) and External Party Acknowledgment (EPA) shall be signed by the third-party and their sub-contractors who handle DEWA data prior to the contract commencement.
- DEWA reserves the right to withhold data from third parties if deemed sensitive.
- Access to data must be restricted to authorized, named third-party employees only and DEWA must be informed of any changes in employment status of those with access.
- Third party shall not disclose, transfer or share any DEWA data with other third parties (government, semi government, private) without obtaining DEWA's authorized data owner written approval.
- Upon the completion/ termination of the agreement the external party shall securely delete all DEWA's data in their custody/ control including the backup and provide written confirmation and evidence to DEWA upon the data deletion completion as per agreed data disposal process, this is to address risk of data remanence.

9) Liquidated Damages for PO total value in excess of AED 50,000:

If the Contractor/Supplier delays or fails to deliver, fails to commence or perform the services, DEWA has the right to deduct an amount equal to 1.25% per day/week of the total PO fee for the services/supplies delayed, not performed or not delivered, subject to a cap of 10% of the total PO fee without recourse to any judicial proceedings, as compensation for the delay or failure to perform. If the deducted amount exceeds 10% of the total PO fee, without prejudice to any of DEWA's rights under the applicable law, DEWA shall be entitled to terminate the PO immediately without the need for any notice or judicial proceedings against the defaulting Supplier, and without the need to prove the damage.

10) Indemnity: The Supplier shall indemnify DEWA from and against all claims, damages, costs and liabilities brought by any third party against DEWA arising out of or in connection with any of acts or omissions of the Supplier/Contractor, or any failure to perform its obligations under this PO.

11) Dispute Resolution: Any dispute arising out of or in connection with this PO shall be settled through mutual good faith negotiation and understanding between the Parties: Failing amicable settlement, the dispute shall finally be referred to the courts having appropriate jurisdiction in the Emirate of Dubai.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER	: 2492600549
DATE	: 09.09.2026
REQ No	: 1172600795
REQ TITLE	: 1 Portable Capacitance Bridge
DELIVERY LOCATION	: 0051 - CS WRSN, TRNSMSN
CLOSING DATE	: 15.09.2026
CLOSING TIME	: 10:00:00

12) Intellectual Property Rights: The Supplier/Contractor shall not use DEWA's intellectual property, including logos, trademarks, service marks, trade names, service names, and brand names, whether in a press release or otherwise, without obtaining DEWA's prior written consent. All intellectual property rights in the deliverables created or developed, under this PO, shall be solely owned by DEWA.

13) Assignment and Transfer: The Supplier/Contractor shall not assign this PO or any part thereof without the prior written consent of DEWA. Such consent shall not relieve the Contractor of any of its obligations or duties under this PO.

14) Force Majeure: If either party is affected by a Force Majeure event, it will promptly notify the other party of the nature and extent thereof. Neither party will be deemed to be in breach of this PO, by reason of any delay or non-performance, of any of its obligations hereunder, due to any Force Majeure event of which it has notified the other party. The time for performance of these obligations will be extended accordingly as may be fair and reasonable in the circumstances. Provided always that if the duration of such delay or impediment exceeds thirty (30) days, either party may give a fifteen (15) working days' notice to terminate a specific item or the PO in its entirety.

15) Certificate of Conformity for Green Materials and Services Specifications: The Bidder shall, wherever applicable, provide a Certificate of conformity issued by accredited body/ laboratory as proof of compliance with the applicable green materials, services and specifications.

16) Taking Over Certificate: TOC shall be issued only after full delivery or completion of the service or deliverables. TOC will be issued conditionally ("conditional TOC") with the reasonable guarantee/observation in case of any defects after delivery or completion of the PO.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2492600549
DATE : 09.09.2026
REQ No : 1172600795
REQ TITLE : 1 Portable Capacitance Bridge
DELIVERY LOCATION : 0051 - CS WRSN, TRNSMSN
CLOSING DATE : 15.09.2026
CLOSING TIME : 10:00:00

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP