REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2492600802

DATE : 12.11.2026
REQ No : 1172601028
REQ TITLE : Multitest instrument 1172601028
DELIVERY LOCATION : 0051 - CS WRSN, TRNSMSN
CLOSING DATE : 18.11.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1	7000000013		MULTIFUNCTION TRANSFORMER TESTING KIT.THIS DOCUMENT DEFINES THE TECHNICAL SPECIFICATIONS FOR A SINGLETRANSFORMER TESTING KIT INTENDE D FOR COMPREHENSIVE ON-SITE TESTING OFPOWER AND DISTRIBUTION TRANSFORMERS. THE KIT SHALL SUPPORT RELIABLEPERFORMANCE DIAGNOSTICS, FA ULT DETECTION, CONDITION ASSESSMENT, SAFETY,EFFICIENCY, AND HIGH-QUALITY OPERATION IN INDUSTRIAL ENVIRONMENTS.THE SUPPLIER SHALL PRO VIDE A COMPLETE, INTEGRATED, PORTABLE, ANDFIELD-PROVEN MULTIFUNCTION TRANSFORMER TEST SYSTEM, INCLUDING ALLHARDWARE MODULES, TEST LE ADS, CLAMPS, SAFETY INTERLOCKS, EARTHINGCABLES, ACCESSORIES, TRANSPORT CASES, SOFTWARE, LICENSES, CALIBRATIONCERTIFICATES, OPERATING MANUALS, REPORT GENERATION SOFTWARE, ANDREQUIRED TRAINING. THE KIT SHALL BE SUITABLE FOR OUTDOOR	1	EA				

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2492600802

DATE : 12.11.2026
REQ No : 1172601028
REQ TITLE : Multitest instrument 1172601028
DELIVERY LOCATION : 0051 - CS WRSN, TRNSMSN
CLOSING DATE : 18.11.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SUBSTATIONENVIRONMENTS AND SHALL E NABLE TESTING WITH MINIMUM RECONNECTION EFFORTFOR AT LEAST 3 OF FOLLOWING MANDATORY TESTS:1. INSULATION RESISTANCE (IR)2. TRANSFORME R TURNS RATIO (TTR)3. DYNAMIC RESISTANCE MEASUREMENT FOR OLTC TESTING.4. SHORT-CIRCUIT IMPEDANCE5. CAPACITANCE & TAN DELTA*IMPORTANT NOTES:# THE SERVICE PROVIDER IS REQUIRED TO PROVIDE DETAILED FEEDBACK FOR EACHFEATURE LISTED BELOW TO FACILITATE THE TECHNICAL EVAL UATION PROCESS.# THE BIDDER SHALL SUBMIT A QUOTATION FOR SINGLE TESTING KIT ONLY.QUOTATIONS OFFERING MORE THAN ONE TESTING KIT SHALL BE DEEMEDNON-COMPLIANT AND REJECTED FROM FURTHER TECHNICAL EVALUATION.# THE BIDDER CAN SUBMIT ALTERNATIVE TESTING KIT IN SEPARATE Q UOTATIONSIF REQUIRED.GENERAL SPECIFICATION SERVICE PROVIDER FEEDBACKSAFETY						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2492600802

DATE : 12.11.2026
REQ No : 1172601028
REQ TITLE : Multitest instrument 1172601028
DELIVERY LOCATION : 0051 - CS WRSN, TRNSMSN
CLOSING DATE : 18.11.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			COMPLIANCE: MUST SUPPORT TRANSFORMER TESTING WITH APPROPR IATEINSULATION AND SAFETY MECHANISMS TO PREVENT ELECTRICAL HAZARDS.# IEC 61010-1 SAFETY COMPLIANCE# CE MARKING OR EQUIVALENT INTERNA TIONAL CERTIFICATION# OVER-VOLTAGE AND THERMAL PROTECTION FEATURES.# SAFETY SWITCHES / STROBE LIGHTS AND BUZZER TO BE PROVIDEDINTERL OCKS AND ALERTS: SYSTEM SHALL PREVENT UNSAFE OPERATION UNDERINCORRECT GROUNDING, OVERLOAD, OVER-TEMPERATURE, OR ABNORMAL CONNECTIONC ONDITIONSRUGGED CONSTRUCTION INCLUDES ALL THE ACCESSORIES : THE SYSTEM SHALL BEMODULAR OR INTEGRATED, HIGH-END, PORTABLE WITH WHEELS , AND SUITABLE FORFIELD USE IN ENERGIZED 400KV/132KV SUBSTATION ENVIRONMENTS.MEASUREMENT ACCURACY: HIGH-PRECISION MEASUREMENT SUITAB LE FORTRANSMISSION POWER TRANSFORMER					

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2492600802

DATE : 12.11.2026
REQ No : 1172601028
REQ TITLE : Multitest instrument 1172601028
DELIVERY LOCATION : 0051 - CS WRSN, TRNSMSN
CLOSING DATE : 18.11.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			DIAGNOSTICS; SUPPLIER TO STATE ACCURACYFOR EACH TEST FUNCTION.*SUITABLE FOR POWER TRANSFORMERS FROM 500KVA TO 90MVAAUTOMATED KIT WITH GENERATED REPORTING: THE SYSTEM SHALL SUPPORTTHREE-PHASE TRANSFORMER TESTING, WHERE TECHNICAL LY APPLICABLE, WITHAUTOMATED TEST SEQUENCING AND GUIDED CONNECTION DIAGRAMS.SPEED AND EFFICIENCY: THE KIT SHALL BE CAPABLE OF COMPLE TING AT LEASTTHREE OF THE MANDATORY TESTS CONSIDERING THE REQUIRED TESTING DURATIONFOR A 19-TAP TRANSFORMER WITH MINIMUM CONNECTION/ DISCONNECTION SEQUENCE.*MENTION THE APPLICABLE MANDATORY TESTS.*MENTION THE CONNECTION/DISCONNECTION SEQUENCE REQUIRED*MENTION THE E XPECTED OVERALL TESTS DURATIONDEMAGNETIZATION OF CORE: THE KIT SHALL PROVIDE AN AUTOMATIC TRANSFORMERCORE DEMAGNETIZATION						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2492600802

DATE : 12.11.2026
REQ No : 1172601028
REQ TITLE : Multitest instrument 1172601028
DELIVERY LOCATION : 0051 - CS WRSN, TRNSMSN
CLOSING DATE : 18.11.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			FUNCTION A FTER DC WINDING RESISTANCE OR OTHERMAGNETIZING TESTS. THE DEMAGNETIZATION PROCESS SHALL BE CONTROLLED,SAFE, AND DOCUMENTED, WITH CLE AR INDICATION OF PROGRESS AND COMPLETION.MEASUREMENT LEADS: AT LEAST 15 M WITH CLAMP.AUTOMATED OLTC OPERATION: THE SYSTEM SHALL AUTO MATICALLY CHANGE TAPPOSITIONS WHILE PERFORMING THE REQUIRED TESTS.SOFTWARE INTEGRATION: THE KIT SHOULD INCLUDE USER-FRIENDLY SOFTWAR E WITHLAPTOP FOR GENERATING REPORTS IN CSV, EXCEL, WORD, AND EDITABLE PDFFORMATS. THE REPORTS INCLUDES ASSET DETAILS, TEST SETTINGS, MEASUREDVALUES, GRAPHS, COMPARISON RESULTS, TEMPERATURE CORRECTION AND OPERATORDETAILS.*LIFETIME SOFTWAREPOWER REQUIREMENTS: OPERAT ES ON STANDARD INDUSTRIAL VOLTAGE (110#240VAC)ENVIRONMENTAL CONDITIONS:						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2492600802

DATE : 12.11.2026
REQ No : 1172601028
REQ TITLE : Multitest instrument 1172601028
DELIVERY LOCATION : 0051 - CS WRSN, TRNSMSN
CLOSING DATE : 18.11.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			OPERATING TEMPERATURE: #10ºC TO +55ºC, STORAGETEMPERATURE - 0 TO 70 ºC, & IP RATING: IP54 OR HIGHERLAPTOP & COMMUNICATION PORTS: LAPTOP SHALL BE ROBUST AND SUITABLE FORFILED USE, INTEL CORE I7 OR SUPERIOR, 16 GB RAM OR HIGHER, 1 TB HDD ORHIGHER AND LATEST VERSION OF WINDOWS ENTERPRISE. THE KIT SHALL INCLUDETHE REQUIRED COM MUNICATION INTERFACE AND PORTS FOR LAPTOP CONNECTIVITY.AVAILABILITY: TECHNICAL SUPPORT, SPARE PARTS & ACCESSORIES SHALL BEAVAILABLE IN THE UAE OR REGIONAL MARKET. MOREOVER, THE SUPPLIER SHALLGUARANTEE THE AVAILABILITY OF CRITICAL SPARE PARTS AND ACCESSORIES FORA T LEAST TEN YEARS FROM THE DATE OF SUPPLY.MAINTENANCE: EASY ACCESS FOR CLEANING AND REPLACING PARTS. INCLUDESSELF-DIAGNOSTIC TOOLS A ND ERROR ALERTS.DEMONSTRATION: A SITE					

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2492600802

DATE : 12.11.2026
REQ No : 1172601028
REQ TITLE : Multitest instrument 1172601028
DELIVERY LOCATION : 0051 - CS WRSN, TRNSMSN
CLOSING DATE : 18.11.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			DEMONSTRATION IS MANDATORY AND MUST BE CONDUCTEDPRIOR TO THE ISSUANCE OF ANY PURCHASE ORDER.TR AINING: FEATURE TRAINING IS REQUIRED AND SHALL BE CONDUCTED FOLLOWINGTHE ISSUANCE OF ANY PURCHASE ORDER.*SITE & THEORETICAL TRAINING O&M: PRINTED OPERATION AND MAINTENANCE DOCUMENTWARRANTY: MINIMUM 2-YEAR WARRANTYCALIBRATION: FACTORY CALIBRATION CERTIFICATE AND RE COMMENDEDCALIBRATION INTERVAL TO BE STATED.MANDATORY TEST FUNCTIONS (AT LEAST 3 TESTS)TRANSFORMER TURNS RATIO (TTR):# THE KIT SHALL MEASURE TRANSFORMER TURNS RATIO FOR SINGLE-PHASE ANDTHREE-PHASE TRANSFORMERS ACROSS ALL TAP POSITIONS.# THE SYSTEM SHALL AUTOMATICAL LY IDENTIFY OR VERIFY VECTOR GROUP,POLARITY, PHASE DISPLACEMENT, EXCITATION CURRENT, AND RATIO DEVIATION.# MINIMUM RATIO RANGE SHALL					

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2492600802

DATE : 12.11.2026
REQ No : 1172601028
REQ TITLE : Multitest instrument 1172601028
DELIVERY LOCATION : 0051 - CS WRSN, TRNSMSN
CLOSING DATE : 18.11.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			BE UP TO 10,000:1 OR BETTER, WITH ACCURACY±0.1% OR BETTER.# THE SYSTEM SHALL SUPPORT AUTOMATIC TAP-BY-TAP TEST SEQUENCING WHERESITE CONDITIONS AND SAFETY PROCEDURES PERMIT.ESTIMATED TESTING DURATION FOR A 19-TAP (R,Y&B)DYNAMIC RESISTANCE MEASUREMENT FOR OLTC TEST ING:# THE KIT SHALL MEASURE DC WINDING RESISTANCE OF TRANSFORMER WINDINGSFOR ALL PHASES AND TAP POSITIONS UP TO 1000 #.# THE TEST CU RRENT SHALL BE SELECTABLE AND SUITABLE FOR POWERTRANSFORMER WINDINGS, PREFERABLY UP TO 50 A DC OR HIGHER WHEREAPPLICABLE.# THE KIT S HALL PERFORM DYNAMIC RESISTANCE MEASUREMENT (DRM) FOR ON-LOADTAP CHANGER (OLTC) CONDITION ASSESSMENT.# THE SYSTEM SHALL RECORD RESIS TANCE/CURRENT VARIATIONS DURING TAPTRANSITION TO IDENTIFY CONTACT WEAR, TRANSITION RESISTOR DEFECTS,					

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2492600802

DATE : 12.11.2026
REQ No : 1172601028
REQ TITLE : Multitest instrument 1172601028
DELIVERY LOCATION : 0051 - CS WRSN, TRNSMSN
CLOSING DATE : 18.11.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			TIMINGABNORMALITIES, OPEN CIRCU ITS, AND MECHANICAL IRREGULARITIES.# THE SYSTEM SHALL PROVIDE HIGH-RESOLUTION GRAPHICAL TRACES, EVENTMARKERS, TAP POSITION LOGGING, AND COMPARISON BETWEEN PHASES ANDHISTORICAL RESULTS.# THE SUPPLIER SHOULD INCLUDE ALL ACCESSORIES, CONTROL INTERFACES, ANDSAFE CONNE CTION METHODS REQUIRED FOR OLTC TESTING.# TEMPERATURE CORRECTION FEATURE.ESTIMATED TESTING DURATION FOR A 19-TAP TRANSFORMER COVERIN G R, Y, AND BPHASES.SHORT-CIRCUIT IMPEDANCE:# THE KIT SHALL MEASURE SHORT-CIRCUIT IMPEDANCE AND LEAKAGE REACTANCEFOR TRANSFORMER WIN DING MECHANICAL CONDITION ASSESSMENT AND COMPARISONWITH FACTORY/SITE ACCEPTANCE VALUES.# THE TEST SHALL SUPPORT THREE-PHASE AND SING LE-PHASE MEASUREMENTMETHODS AS APPLICABLE TO TRANSFORMER DESIGN AND SITE					

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2492600802

DATE : 12.11.2026
REQ No : 1172601028
REQ TITLE : Multitest instrument 1172601028
DELIVERY LOCATION : 0051 - CS WRSN, TRNSMSN
CLOSING DATE : 18.11.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			CONNECTIONS.# THE SYSTEM SHALL MEASURE APPLIED VOLTAGE, CUR RENT, PHASE ANGLE,IMPEDANCE, REACTANCE, AND CALCULATED PERCENTAGE IMPEDANCE.# THE SYSTEM SHALL GENERATE REPORTS SUITABLE FOR COMPARI SON AGAINSTNAMEPLATE, SAT, FAT, AND HISTORICAL RECORDSESTIMATED TESTING DURATION FOR A 19-TAP TRANSFORMER COVERING R, Y, AND BPHASES .TAN DELTA AND CAPACITANCE:# THE KIT SHALL PERFORM CAPACITANCE AND DIELECTRIC DISSIPATION FACTOR /POWER FACTOR / TAN DELTA MEASUREME NT FOR TRANSFORMER WINDINGS, BUSHINGS,AND INSULATION SYSTEMS.# THE SYSTEM SHALL SUPPORT GROUNDED SPECIMEN TEST (GST), UNGROUNDEDSPEC IMEN TEST (UST), GST-GUARD, AND OTHER STANDARD MEASUREMENT MODESREQUIRED FOR TRANSFORMER AND BUSHING DIAGNOSTICS.# THE HIGH-VOLTAGE OUTPUT SHALL BE SUITABLE FOR FIELD						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2492600802

DATE : 12.11.2026
REQ No : 1172601028
REQ TITLE : Multitest instrument 1172601028
DELIVERY LOCATION : 0051 - CS WRSN, TRNSMSN
CLOSING DATE : 18.11.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			DIELECTRICTESTING, PREFERABLY UP TO 12 KV AC OR HIGHER, WITH ADEQUATE CURRENT ANDPOWER CAPACITY F OR TRANSFORMER WINDING AND BUSHING CAPACITANCEMEASUREMENTS.# THE SYSTEM SHALL MEASURE CAPACITANCE, TAN DELTA / DISSIPATION FACTOR,PO WER FACTOR, TEST VOLTAGE, CURRENT, WATTS LOSS, ANDINTERFERENCE-SUPPRESSED RESULTS.# RANGE# CAPACITANCE RANGE 20 NF @ 12 KV RMS @ 50 HZ, 0.						

TOTAL AMOUNT IN WORDS: TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:
Multitest instrument

STANDARD TERMS & CONDITIONS

1) RFQ Document Disclaimer: The PDF version of this Request for Quotation (RFQ) is provided for convenience only and contains a summary of key information. It does not include all technical details, requirements, or specifications. Bidders must refer to the complete system documentation and all referenced materials to obtain full and accurate information necessary for preparing their proposals.

2) Prices should be 'DDP' delivery duty paid at DEWA stores.

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER	: 2492600802
DATE	: 12.11.2026
REQ No	: 1172601028
REQ TITLE	: Multitest instrument 1172601028
DELIVERY LOCATION	: 0051 - CS WRSN, TRNSMSN
CLOSING DATE	: 18.11.2026
CLOSING TIME	: 10:00:00

3) Quotation to be submitted only in local currency U.A.E Dirhams

4) DEWA Standard Payments: Payment will be made within 30 days from the date the Supplier/Contractor submits a complete and accurate invoice, together with all required supporting documents, subject to the material and/or services having been duly accepted.

5) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.

6) The offered product and/or services in the Quotation, shall be confirming and in accordance with DEWA Energy Management Policy & EnMS Manual.

7) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer. If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements. The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

8)Data Privacy, Security and Sharing:
a) Third-party shall handle DEWA data in accordance with all applicable laws, regulations, and DEWA policies.
b) DEWA data shall not be shared outside UAE, in line with DESC ISR requirements.
c) DEWA's Non-Disclosure Agreement (NDA) and External Party Acknowledgment (EPA) shall be signed by the third-party and their sub-contractors who handle DEWA data prior to the contract commencement.
d) DEWA reserves the right to withhold data from third parties if deemed sensitive.
e) Access to data must be restricted to authorized, named third-party employees only and DEWA must be informed of any changes in employment status of those with access.
f) Third party shall not disclose, transfer or share any DEWA data with other third parties (government, semi government, private) without obtaining DEWA#s authorized data owner written approval.

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER	: 2492600802
DATE	: 12.11.2026
REQ No	: 1172601028
REQ TITLE	: Multitest instrument 1172601028
DELIVERY LOCATION	: 0051 - CS WRSN, TRNSMSN
CLOSING DATE	: 18.11.2026
CLOSING TIME	: 10:00:00

g) Upon the completion/ termination of the agreement the external party shall securely delete all DEWA#s data in their custody/ control including the backup and provide written confirmation and evidence to DEWA upon the data deletion completion as per agreed data disposal process, this is to address risk of data remanence.

9) Liquidated Damages for PO total value in excess of AED 50,000:
If the Contractor/Supplier delays or fails to deliver, fails to commence or perform the services, DEWA has the right to deduct an amount equal to 1.25% per day/week of the total PO fee for the services/supplies delayed, not performed or not delivered, subject to a cap of 10% of the total PO fee without recourse to any judicial proceedings, as compensation for the delay or failure to perform. If the deducted amount exceeds 10% of the total PO fee, without prejudice to any of DEWA's rights under the applicable law, DEWA shall be entitled to terminate the PO immediately without the need for any notice or judicial proceedings against the defaulting Supplier, and without the need to prove the damage.

10) Indemnity: The Supplier shall indemnify DEWA from and against all claims, damages, costs and liabilities brought by any third party against DEWA arising out of or in connection with any of acts or omissions of the Supplier/Contractor, or any failure to perform its obligations under this PO.

11) Dispute Resolution: Any dispute arising out of or in connection with this PO shall be settled through mutual good faith negotiation and understanding between the Parties: Failing amicable settlement, the dispute shall finally be referred to the courts having appropriate jurisdiction in the Emirate of Dubai.

12) Intellectual Property Rights: The Supplier/Contractor shall not use DEWA's intellectual property, including logos, trademarks, service marks, trade names, service names, and brand names, whether in a press release or otherwise, without obtaining DEWA's prior written consent. All intellectual property rights in the deliverables created or developed, under this PO, shall be solely owned by DEWA.

13) Assignment and Transfer: The Supplier/Contractor shall not assign this PO or any part thereof without the prior written consent of DEWA. Such consent shall not relieve the Contractor of any of its obligations or duties under this PO.

14) Force Majeure: If either party is affected by a Force Majeure event, it will promptly notify the other party of the nature and extent thereof. Neither party will be deemed to be in breach of this PO, by reason of any delay or non-performance, of any of its obligations hereunder, due to any Force Majeure event of which it has notified the other party. The time for performance of these obligations will be extended accordingly as may be fair and reasonable in the circumstances. Provided always that if the duration of such delay or impediment exceeds thirty (30) days, either party may give a fifteen (15) working days' notice to terminate a specific item or the PO in its entirety.

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER	: 2492600802
DATE	: 12.11.2026
REQ No	: 1172601028
REQ TITLE	: Multitest instrument 1172601028
DELIVERY LOCATION	: 0051 - CS WRSN, TRNSMSN
CLOSING DATE	: 18.11.2026
CLOSING TIME	: 10:00:00

15) Certificate of Conformity for Green Materials and Services Specifications: The Bidder shall, wherever applicable, provide a Certificate of conformity issued by accredited body/ laboratory as proof of compliance with the applicable green materials, services and specifications.

16) Taking Over Certificate: TOC shall be issued only after full delivery or completion of the service or deliverables. TOC will be issued conditionally ("conditional TOC") with the reasonable guarantee/observation in case of any defects after delivery or completion of the PO.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP

DISCLAIMER : THIS IS A SYSTEM GENERATED DOCUMENT , DOSEN'T NEED SIGNATURE.