

Ref: SMCS/GEN/266/2009

29.07.2009

All Consultants and Electrical Contractors
Dubai

Dear Sir,

Provision of Building Substation
within Petrol Filling Station premises/plots

The Authority is constantly endeavoring to provide safe and reliable power supply to its consumers. We thank you for your valuable co-operation and co-ordination with us to provide you the best services.

In order to improve safety and reliability of power supply in specific locations, we request your attention to ensure compliance with the following requirements in your design:-

- For plots/premises of Petrol Filling Stations where requirement to build a substation is specified in DEWA's Building NOC s, only Building-type Substations (with RCC roof) shall be permitted.
- Any proposal to install Pocket-type Substations in such locations shall not be approved by DEWA.

Please arrange necessary action form your end accordingly.

Assuring our best services at all the times.

Thanking you,

Yours faithfully,
For DUBAI ELECTRICITY & WATER AUTHORITY


Obaid Saif Al Falasi
(Senior Manager – Connection Services)



Sword of Honour
BRITISH SAFETY COUNCIL